LMS
Construction Services Ltd

RISK ASSESSMENT NO. 15 – Paddle Mixer	
Location	Shettleston Telephone Exchange
Task/Activities	Mixing Materials
Other Information	N/A

RISK ASSESSMENT SIGN OFF					
Prepared by	Leigh Satti	Signature		Date	04/06/2025
Date for review	04/07/2025				

RISK MATRIX								
Risk Rating Guidance	Likelihood (L)	5	5	10	15	20	25	Likelihood (L) x Severity (S) = Risk Rating (RR)
		4	4	8	12	16	20	
		3	3	6	9	12	15	
		2	2	4	6	8	10	
		1	1	2	3	4	5	
			1	2	3	4	5	
		Severity (S)						
Acceptability of Risk Guidance	High Risk: 15-25	High-risk activities should cease immediately. Further effective control measures to mitigate risks must be introduced.						
	Medium Risk: 8-12	Medium risks should only be tolerated for the short term and only whilst further control measures to mitigate the risks are being planned and introduced.						
	Low Risk: 1-6	Low risks are largely acceptable. Where it is reasonable to do so efforts should be made to reduce risks further.						
Guidance. When completing a risk assessment, you should:	1. Identify the persons at risk and the significant hazards. 2. Calculate an initial RR for the activity. 3. Identify risk control measures that reduce the risks to an acceptable level. 4. Calculate a revised RR – you should consider how much safer the task will be if the control measures are followed. Here, you should consider changing both the likelihood (L) and the severity (S) ratings.							
Note: Ideally, you should look to reduce the risks so that the task can be classified as 'low risk'.								

LMS
Construction Services Ltd
Telephone: 01383 252052
Email: info@lms-cs.co.uk
Website: www.lmsconstructionservices.co.uk
Address: 7A Crossway, Hillend Ind Est, Dalgety Bay, KY11 9JE
Company Reg:732922

LMS
Construction Services Ltd

PERSONAL PROTECTIVE EQUIPMENT (P.P.E.) ASSESSMENT								
In many instances, you will be able to reduce risks further by asking staff/others to wear/use P.P.E. You should identify which items are required for the task here:								
Type of P.P.E.								
	Head	Foot	Eye	Hand	Hearing	High-Visibility Vest	RPE	Fall Arrest
	✓	✓	✓	✓	✓	✓	✓	o
Additional Requirements	Operatives will conform to Clients H&S standards. Face covering are required to be worn when getting to and from site and when moving around site							
Note: P.P.E. must only be considered as, when other control measures, such as guarding, local exhaust extraction, preventing noise at source, eliminating the need to work at height etc. are not possible. P.P.E. should always be considered as a last resort option. P.P.E. should only be worn when there is reasonable justification for doing so.								

Persons at Risk						
	LMS Employees	✓	Visitors to Site	✓	Members of the Public	o
	Clients Employees	✓	Contractors Employees	✓	Others	o

LMS
Construction Services Ltd
Telephone: 01383 252052
Email: info@lms-cs.co.uk
Website: www.lmsconstructionservices.co.uk
Address: 7A Crossway, Hillend Ind Est, Dalgety Bay, KY11 9JE
Company Reg:732922

LMS
Construction Services Ltd

Significant Hazards	How You May be Harmed	Initial			Risk Control Measures	Residual		
		L	S	RR		L	S	RR
Covid-19	Illness, Serious Illness, or Death	5	5	25	• Gloves are to be use when using tools. • Tools are to be wiped down after each use. • Ensure a supply of hygiene gel and wipes are available for use. • Ensure the 2m distancing guidelines are adhered to while working on scaffold. • Facemasks to be worn on site and social distancing maintained. • Strict hygiene standards to be maintained. • Discrete work groups. • Advise Supervisor immediately if you start to display Covid like symptoms, or you are contacted by Test and Protect or a member of your immediate family tests positive or has to isolate.	2	5	10
Dust / Spray from use of equipment	Operatives could suffer short term or long-term lung disease, from exposure to dust mixed with the water spray.	3	3	9	• Identify the material that is being worked upon and the COSHH precautions required. • Appropriate task-based facemask must be worn - minimum of FFP 3. Air fed masks are also available. • Safety Glasses and appropriate hearing protection should also be worn.	1	2	2
Noise	Working in close proximity to equipment for extended periods might cause temporary hearing loss or long-term damage	2	3	6	• Signage to be displayed advising of noise requirements (if appropriate) • Wear ear defenders. • Quieter equipment sourced whenever possible • Sound proofing and job rotation away from noise of the gas torch	1	2	2

LMS
Construction Services Ltd
Telephone: 01383 252052
Email: info@lms-cs.co.uk
Website: www.lmsconstructionservices.co.uk
Address: 7A Crossway, Hillend Ind Est, Dalgety Bay, KY11 9JE
Company Reg:732922

Electrical equipment - faulty equipment and striking services	Operatives could receive electrical shocks or burns.	4	4	16	• Ensure equipment is maintained and in good condition before use DO NOT USE FAULTY EQUIPMENT. • Use equipment as per manufacturers recommendations. • Do not use circular saw in flammable atmosphere or near combustible materials / substances. • Ensure no hidden hazards such as electric wiring, water pipes, gas pipes etc. • Where services are identified minimum distance of 150mm to be maintained when using power tools • Only 110V electrical equipment to be used. • PAT tested and in date. • Staff trained to identify and report any defects or damage to supervisor and Site Manager.	1	4	4
Hand-arm Vibration	Operatives could suffer circulation problems in hands from over exposure.	2	3	6	• Emission levels considered prior to purchase. • All operators provided with training, information and use of PPE. • Machines maintained by manufacturer. • Trigger Time to EAV 360min • Trigger Time to ELV 1440min • Work sequences will be planned and job rotation introduced where demands require longer usage. • Identified PPE to be worn correctly. • Site Foreman to monitor compliance and adequacy of control measures in place.	1	3	3
Manual Handling	Operatives could suffer from back injury and short term or long-term pain if regularly lifting/carrying	3	3	9	• Operatives to be experienced in manual handling techniques. • Handling of equipment, to be considered carefully prior to commencing the task. • Ensure that the items to be cut are handled appropriately.	1	3	3

LMS
Construction Services Ltd
Telephone: 01383 252052
Email: info@lms-cs.co.uk
Website: www.lmsconstructionservices.co.uk
Address: 7A Crossway, Hillend Ind Est, Dalgety Bay, KY11 9JE
Company Reg:732922

	heavy objects and incorrect techniques applied				• Mechanical handling aids provided for movement of waste materials. • Refer to manual handling assessments for raising and movement of materials as appropriate.			
Sharp Objects	Operatives receive cuts or abrasions from tools	3	4	12	• A visual check to be carried out before use to check tools are in a safe condition e.g., no burrs, split handles, loose hammer heads, splayed spanner heads etc. damaged tools to be repaired or replaced immediately. • Covers to be fitted to sharp edges such as Knife blades and saw edges when not in use. • Tools such as cutters and scissors to be kept in closed position when not in use.	1	3	3
Slips, Trips and Falls	Serious injury or even fatal injury could occur if a worker falls.	4	4	16	• Ensure appropriate cleaning and housekeeping practices are maintained to minimise the risk of slips, trips and falls. • Keep trailing leads tidy. • Tidy up waste throughout and at the end of the day. • If inclement weather occurs be mindful of increased risk of slippery surfaces. • Wear appropriate footwear.	1	3	3

LMS
Construction Services Ltd
Telephone: 01383 252052
Email: info@lms-cs.co.uk
Website: www.lmsconstructionservices.co.uk
Address: 7A Crossway, Hillend Ind Est, Dalgety Bay, KY11 9JE
Company Reg:732922