HEALTH AND SAFETY RISK ASSESSMENT - Rev0

Site: GXO – Decathlon Wellingborough

Location: 39-44 Davy Close, Park Farm, Wellingborough, NN8 6XX

Activity: Cylindrical Tank TDRB

Person preparing assessment: Ian Sneddon

Date: 3/5/2023

Position: Project Manager

Contract No: 24-T4265

Approx. Dismantle Start Date: 20/5/2024
Approx. Erection Start Date: 10/6/2024

Persons Exposed:

Construction employees: 2-4 CSTV Ltd employees: 0

Hazards which create potential for harm

Mobile Plant/vehicles	Falls of Materials	Fire/Explosion	Confined Spaces
Visiting Traffic	Noise/Vibration	Flying Particles	Overhead
Demolition	Fumes / Gas	Structure Collapse	Underground Services
Deep Excavations	Dust	Infected Material	Manual Handing
Falls From Height	Heat	Soft Ground	Vehicle Overturning
Falls on Level	Lifting Levels	Lighting Levels	Adverse Weather

Other risk (specify): COVID-19 Corona Virus

Notes: -

1. Likelihood of harm: Likely = 3, Possible = 2, Unlikely = 1
   Severity of harm: Major injury/death = 3, Notifiable = 2, Minor injury = 1

2. If, following controls there appears a result greater than or equal to 4 in column 7
   then refer the assessment to your Health and Manager for a review of the controls.
   Further controls should be implemented to reduce the degree of risk.

3. If our operations are likely to affect pedestrians, the control measures must reduce the likelihood of
   significant harm to the level that existed before our work commended.

Low = 1 to 3
Medium = 4 to 7
High = 8 to 9

Hazard	1	2	3	4	5	6	7	8
	Factors of Harm		Risk	Control Measures	Likelihood See note 1	Severity See note 1	Residual Risk	Control Measures
	Likelihood See note 1	Severity See note 1	Multiple of Columns 1&2				Multiple of Columns 1&2	
Mobile plant / Vehicles	2	3	6	All operatives must be isolated away from other contractor's work activities. Barriers to be installed to act as a visual and physical barrier. Operatives to report any mobile plant encroaching on working area. Plant must not operate near confined spaces.	1	3	3	ALL
Manual Handling	2	2	4	Use mechanical means where possible. Heavy items must not be lifted by one person. When unloading tank kits, kits should be placed as close to the tank base as possible to reduce the distance. Sheets must be carried by 2 operatives. Operatives to be trained in Manual Handling Operations.	1	2	2	ALL
Noise	2	2	4	Noise is not considered to be excessive during the installation works. Ear defenders to be worn when tightening tank bolts or using power tools.	1	2	2	Foreman

HEALTH AND SAFETY ASSESSMENT (CONTINUED SHEET)

R/A No:

Hazard	1	2	3	4	5	6	7	8
	Factors of Harm		Risk	Control Measures	Likelihood See note 1	Severity See note 1	Residual Risk	Control Measures
	Likelihood See note 1	Severity See note 1	Multiple of Columns 1&2				Multiple of Columns 1&2	
Slipping / Tripping	2	2	4	Access around the tank must be adequate and generally on a level compacted ground (Concrete hardstand). Prevent slips, trips and falls by keeping the work area tidy. All cables to be tidied away, stop unauthorised personnel approaching the work area.	1	2	2	ALL
Adverse Weather Conditions	3	3	9	Site foreman is fully competent in dismantling & erecting tanks and will make the final decision as to whether work is safe to commence/continue.	1	3	3	Foreman
Falls from height	2	3	6	Due to the methods of dismantle & construction, the need to work at height is vastly reduced. Safety Lanyard & Harness to be used if working at height is required. Permit to be requested from the site office if required.	1	3	3	ALL
Confined Spaces	3	3	9	Employees are trained to work in Confined Spaces. If the site is deemed to be a confined space then the correct procedures need to be determined prior to commencement of activity along with obtaining a Permit to Work. For Confined Spaces a Gas monitor will be present on the inside of tank during the works and employees will carry a 10-minute escape set.	1	3	3	ALL
Use of Hand Tools	2	2	4	All hand tools to be PAT tested and visually inspected prior to use. All tools to be 110V. Wear gloves to keep hands warm and use work rotation where possible, hot works permits are to be requested when required.	1	2	2	Foreman
COSHH	2	2	4	Gloves to be worn when handling Sika Products. Use in adequately ventilated areas. If possible that eye contact is to occur then eye protection	1	2	2	Foreman
Fumes	2	3	6	Generators are used to power hand tools & lifting jacks. Keep generators away from the tank openings.	1	3	3	ALL
Dust	2	3	6	Wear appropriate face masks for the activity being undertaken. Use water suppression to damp down any dust created.	1	3	3	ALL
Untidy Site	2	2	4	Housekeeping must be in order, with no tank kit left on the floor. Restrict to essential personnel.	1	2	2	ALL

Name				
Signature				
Date				