

Month:	Sep/2024
Usage Water (m ³)	617.19
Usage ELEC	
Feeder 1 kW (Max)	945.53
Feeder 1 kWh (Total)	674,121.44
Feeder 2 kW (Max)	2,109.10
Feeder 2 kWh (Total)	1,497,440.88
Feeder Max kW	2,955.64
Feeder Total kWh	2,171,562.31
Chillers indicator	
RT (Max)	4,469.75
RT (Median)	1,085.71
RT (Sum of month)	906,632.64
Temp	
Plot 1 CHWST (Avg °C)	7.47
Plot 1 CHWRT (Avg °C)	9.94
Plot 2 CHWST (Avg °C)	7.43
Plot 2 CHWRT (Avg °C)	12.39
Cooling Load Produced	
Plot 1 (RTh)	259,206.63
Plot 2 (RTh)	607,420.52
EFF Monthly	
Efficiency (Median)	0.65
Efficiency (Avg)	0.66

