

Month:	Sep/2024
Usage Water (m ³)	536.09
Usage ELEC	
Feeder 1 kW (Max)	652.88
Feeder 1 kWh (Total)	741,344.19
Feeder 2 kW (Max)	1,988.85
Feeder 2 kWh (Total)	1,908,395.00
Feeder Max kW	2,235.28
Feeder Total kWh	2,649,739.19
Chillers indicator	
RT (Max)	4,193.17
RT (Median)	1,093.23
RT (Sum of Month)	901,991.56
Temp	
Plot 1 CHWST (Avg °C)	7.09
Plot 1 CHWRT (Avg °C)	9.92
Plot 2 CHWST (Avg °C)	7.07
Plot 2 CHWRT (Avg °C)	11.85
Cooling Load Produced	
Plot 1 (RTh)	283,521.45
Plot 2 (RTh)	595,364.54
EFF Monthly	
Efficiency (Median)	0.63
Efficiency (Avg)	0.65

