

Month:	Nov/2024
Usage Water (m³)	449.69
Usage ELEC	
Feeder 1 kW (Max)	962.53
Feeder 1 kWh (Total)	880,787.94
Feeder 2 kW (Max)	1,840.17
Feeder 2 kWh (Total)	2,347,474.50
Feeder Max kW	2,021.65
Feeder Total kWh	3,228,262.44
Chillers indicator	
RT (Max)	3,052.36
RT (Median)	1,051.45
RT (Sum of Month)	882,333.93
Temp	
Plot 1 CHWST (Avg °C)	7.16
Plot 1 CHWRT (Avg °C)	10.15
Plot 2 CHWST (Avg °C)	7.15
Plot 2 CHWRT (Avg °C)	11.51
Cooling Load Produced	
Plot 1 (RTh)	270,487.94
Plot 2 (RTh)	556,450.76
EFF Monthly	
Efficiency (Median)	0.62
Efficiency (Avg)	0.62

