

Month:	Dec/2024
Usage Water (m ³)	560.64
Usage ELEC	
Feeder 1 kW (Max)	1,290.94
Feeder 1 kWh (Total)	1,233,559.38
Feeder 2 kW (Max)	1,229.23
Feeder 2 kWh (Total)	2,640,108.75
Feeder Max kW	1,957.03
Feeder Total kWh	3,873,668.13
Chillers indicator	
RT (Max)	3,659.06
RT (Median)	1,286.26
RT (Sum of Month)	1,046,857.81
Temp	
Plot 1 CHWST (Avg °C)	6.88
Plot 1 CHWRT (Avg °C)	11.41
Plot 2 CHWST (Avg °C)	6.86
Plot 2 CHWRT (Avg °C)	11.19
Cooling Load Produced	
Plot 1 (RTh)	442,070.44
Plot 2 (RTh)	535,397.06
EFF Monthly	0.606

