

Month:	Feb/2025
Usage Water (m³)	407.74
Usage ELEC	
Feeder 1 kW (Max)	1,494.84
Feeder 1 kWh (Total)	317,886.38
Feeder 2 kW (Max)	1,189.61
Feeder 2 kWh (Total)	161,223.75
Feeder Max kW	2,013.25
Feeder Total kWh	479,110.13
Chillers indicator	
RT (Max)	3,120.04
RT (Median)	995.76
RT (Sum of Month)	763,276.99
Temp	
Plot 1 CHWST (Avg °C)	6.84
Plot 1 CHWRT (Avg °C)	9.16
Plot 2 CHWST (Avg °C)	6.83
Plot 2 CHWRT (Avg °C)	11.86
Cooling Load Produced	
Plot 1 (RTh)	186,803.09
Plot 2 (RTh)	523,697.79
EFF Monthly	0.618

