

Month:	Mar/2025
Usage Water (m³)	520.26
Usage ELEC	
Feeder 1 kW (Max)	1,147.15
Feeder 1 kWh (Total)	288,831.23
Feeder 2 kW (Max)	1,928.53
Feeder 2 kWh (Total)	355,249.70
Feeder Max kW	2,179.77
Feeder Total kWh	644,080.93
Chillers indicator	
RT (Max)	3,719.92
RT (Median)	1,122.87
RT (Sum of Month)	1,014,700.85
Temp	
Plot 1 CHWST (Avg °C)	6.86
Plot 1 CHWRT (Avg °C)	10.64
Plot 2 CHWST (Avg °C)	6.85
Plot 2 CHWRT (Avg °C)	11.85
Cooling Load Produced	
Plot 1 (RTh)	354,482.67
Plot 2 (RTh)	624,422.69
EFF Monthly	0.621

