

Month:	Apr/2025
Usage Water (m³)	659.31
Usage ELEC	
Feeder 1 kW (Max)	1,528.15
Feeder 1 kWh (Total)	295,005.38
Feeder 2 kW (Max)	2,292.33
Feeder 2 kWh (Total)	511,858.00
Feeder Max kW	3,119.15
Feeder Total kWh	806,863.38
Chillers indicator	
RT (Max)	4,679.01
RT (Median)	1,447.65
RT (Sum of Month)	1,276,463.72
Temp	
Plot 1 CHWST (Avg °C)	6.87
Plot 1 CHWRT (Avg °C)	11.57
Plot 2 CHWST (Avg °C)	6.86
Plot 2 CHWRT (Avg °C)	12.02
Cooling Load Produced	
Plot 1 (RTh)	639,766.38
Plot 2 (RTh)	630,387.02
EFF Monthly	0.621

