

| Month:                        | May/2025     |
|-------------------------------|--------------|
| Usage Water (m <sup>3</sup> ) | 763.04       |
| Usage ELEC                    |              |
| Feeder 1 kW (Max)             | 1,252.85     |
| Feeder 1 kWh (Total)          | 265,042.00   |
| Feeder 2 kW (Max)             | 2,473.06     |
| Feeder 2 kWh (Total)          | 626,232.50   |
| Feeder Max kW                 | 3,332.09     |
| Feeder Total kWh              | 891,274.50   |
| Chillers indicator            |              |
| RT (Max)                      | 4,914.30     |
| RT (Median)                   | 1,574.85     |
| RT (Sum of Month)             | 1,403,711.11 |
| Temp                          |              |
| Plot 1 CHWST (Avg °C)         | 6.97         |
| Plot 1 CHWRT (Avg °C)         | 11.82        |
| Plot 2 CHWST (Avg °C)         | 6.96         |
| Plot 2 CHWRT (Avg °C)         | 12.10        |
| Cooling Load Produced         |              |
| Campus Heart (RTh)            | 698,516.64   |
| Campus Court (RTh)            | 694,694.18   |
| SIT Owner (RTh)               | 0.00         |
| SIT Tenants (RTh)             | 0.00         |
| JTC Tenants (RTh)             | 0.00         |
| EFF Monthly                   | 0.624        |
| System uptime (%)             | 100.00%      |

