

Month:	Jun/2025
Usage Water (m ³)	821.24
Usage ELEC	
Feeder 1 kW (Max)	1,793.17
Feeder 1 kWh (Total)	271,695.50
Feeder 2 kW (Max)	2,500.05
Feeder 2 kWh (Total)	652,567.50
Feeder Max kW	3,388.54
Feeder Total kWh	924,263.00
Chillers indicator	
RT (Max)	5,110.88
RT (Median)	1,606.97
RT (Sum of Month)	1,478,821.39
Temp	
Plot 1 CHWST (Avg °C)	6.98
Plot 1 CHWRT (Avg °C)	12.21
Plot 2 CHWST (Avg °C)	6.97
Plot 2 CHWRT (Avg °C)	11.58
Cooling Load Produced	
Campus Heart (RTh)	824,738.32
Campus Court (RTh)	669,843.22
SIT Owner (RTh)	0.00
SIT Tenants (RTh)	0.00
JTC Tenants (RTh)	0.00
EFF Monthly	0.615
System uptime (%)	96.77%

