

Month:	Jul/2025
Usage Water (m³)	895.55
Usage ELEC	
Feeder 1 kW (Max)	1,161.04
Feeder 1 kWh (Total)	303,086.50
Feeder 2 kW (Max)	2,278.19
Feeder 2 kWh (Total)	694,631.00
Feeder Max kW	3,144.75
Feeder Total kWh	997,717.50
Chillers indicator	
RT (Max)	4,835.09
RT (Median)	1,974.25
RT (Sum of Month)	1,624,813.62
Temp	
Plot 1 CHWST (Avg °C)	6.93
Plot 1 CHWRT (Avg °C)	12.20
Plot 2 CHWST (Avg °C)	6.92
Plot 2 CHWRT (Avg °C)	11.65
Cooling Load Produced	
Campus Heart (RTh)	896,625.77
Campus Court (RTh)	754,557.32
SIT Owner (RTh)	0.00
SIT Tenants (RTh)	0.00
JTC Tenants (RTh)	0.00
EFF Monthly	0.604
System uptime (%)	100.00%

