

Month:	Aug/2025
Usage Water (m³)	8336.00
Usage ELEC	
Feeder 1 kW (Max)	1,557.55
Feeder 1 kWh (Total)	395,572.00
Feeder 2 kW (Max)	2,185.25
Feeder 2 kWh (Total)	558,737.00
Feeder Max kW	2,992.83
Feeder Total kWh	954,309.00
Chillers indicator	
RT (Max)	4,622.55
RT (Median)	1,850.48
RT (Sum of Month)	1,550,731.26
Temp	
Campus Heart CHWST (Avg °C)	6.89
Campus Heart CHWRT (Avg °C)	11.78
Campus Court CHWST (Avg °C)	6.88
Campus Court CHWRT (Avg °C)	11.71
Cooling Load Produced	
Campus Heart (RTh)	799,229.27
Campus Court (RTh)	771,280.86
SIT Owner (RTh)	0.00
SIT Tenants (RTh)	0.00
JTC Tenants (RTh)	0.00
Sub Total RTh	1,570,510.13
1-7 Aug RTh	385,511.55
Total RTh (Chargeable to SIT)	1,184,998.58
EFF Monthly	0.607
System uptime (%)	100.00%

