

|                               |              |
|-------------------------------|--------------|
| Month:                        | Oct/2025     |
| Usage Water (m³)              | 9081.08      |
| Usage ELEC                    |              |
| Feeder 1 kW (Max)             | 1,041.31     |
| Feeder 1 kWh (Total)          | 278,253.00   |
| Feeder 2 kW (Max)             | 2,239.98     |
| Feeder 2 kWh (Total)          | 724,716.00   |
| Feeder Max kW                 | 3,051.66     |
| Feeder Total kWh              | 1,002,969.00 |
| Chillers indicator            |              |
| RT (Max)                      | 4,798.20     |
| RT (Median)                   | 1,946.05     |
| RT (Sum of Month)             | 1,627,963.03 |
| Temp                          |              |
| Campus Heart CHWST (Avg °C)   | 6.84         |
| Campus Heart CHWRT (Avg °C)   | 11.32        |
| Campus Court CHWST (Avg °C)   | 6.83         |
| Campus Court CHWRT (Avg °C)   | 12.21        |
| Cooling Load Produced         |              |
| Campus Heart (RTh)            | 831,734.78   |
| Campus Court (RTh)            | 804,148.65   |
| SIT Owner (RTh)               | 0.00         |
| SIT Tenants (RTh)             | 0.00         |
| JTC Tenants (RTh)             | 0.00         |
| Total RTh (Chargeable to SIT) | 1,635,883.42 |
| EFF Monthly                   | 0.604        |
| System uptime (%)             | 99.76%       |

