

Month:	Jan/2026
Usage Water (m³)	7140.10
Usage ELEC	
Feeder 1 kW (Max)	1,273.70
Feeder 1 kWh (Total)	352,000.50
Feeder 2 kW (Max)	1,426.37
Feeder 2 kWh (Total)	426,115.00
Feeder Max kW	2,063.40
Feeder Total kWh	778,115.50
Chillers indicator	
RT (Max)	3,392.64
RT (Median)	1,629.86
RT (Sum of Month)	1,321,778.52
Temp	
Campus Heart CHWST (Avg °C)	6.81
Campus Heart CHWRT (Avg °C)	10.02
Campus Court CHWST (Avg °C)	6.79
Campus Court CHWRT (Avg °C)	11.91
Cooling Load Produced	
Campus Heart (RTh)	577,670.62
Campus Court (RTh)	715,877.65
SIT Owner (RTh)	0.00
SIT Tenants (RTh)	0.00
JTC Tenants (RTh)	0.00
Total RTh (Chargeable to SIT)	1,293,548.27
EFF Monthly	0.581
System uptime (%)	100.00%

