



JAMUNA FABRICATION & ENGINEERING LTD.

ENGINEERING · PROCUREMENT · CONSTRUCTION

Plot #12, BSCIC Industrial Area, Gazipur-1700, Bangladesh · +880 1712 345 678 · procurement@jamunafabrication.com.bd
BIN: 004512367-0101 · VAT Reg.: 19011045897

COMPARATIVE STATEMENT (CS)

DRAFT — FOR APPROVAL

Draft Reference	Draft — official series pending approval (ref. RFQ-2026-000119)
RFQ No.	RFQ-2026-000119
RFQ Title	Substation transformer servicing — service
Project	33/11 kV substation — transformer maintenance window
Delivery Location	Bhaluka factory
Issue Date	Jul 6, 2026
Currency	BDT
Prepared By	Procurement Department

PARTICIPATING VENDORS

#	Vendor	Quotation Ref.	Received	Delivery Offer
1	Dhaka Power Services Ltd.	—	Jun 29, 2026	Shutdown window of 3 days
2	Eastern Grid Engineering	—	Jun 30, 2026	Shutdown window of 2 days
3	Rupsha Electromech	—	Jul 1, 2026	Shutdown window of 4 days

EXECUTIVE SUMMARY [†] buyer-authored

Three (3) quotations were received for the substation transformer servicing scope. All offers were evaluated across 8 service line items on a completed-work basis. Rupsha Electromech offers the lowest evaluated grand total against an in-house test protocol; Dhaka Power Services Ltd. quotes 4.43% above the lowest offer with the full IEC 60422 test protocol and a 12-month gasket warranty. The Procurement Department accepts the compliance premium and recommends award to Dhaka Power Services Ltd., subject to management approval.

[†] Recorded by the buyer's procurement team. The platform computes arithmetic (totals, VAT, lowest-price identification) only and generates no recommendation.

COMMERCIAL SUMMARY

Total Line Items	8
Vendors Compared	3
Lowest Grand Total (computed)	Rupsha Electromech — BDT 818,800.00
Second Lowest (computed)	Dhaka Power Services Ltd. — BDT 856,750.00
Recommended Vendor [†]	Dhaka Power Services Ltd.

APPROVAL

Prepared By	Checked By	Recommended By	Approved By
Md. Asif Hossain Sr. Procurement Executive Date: _____	Nusrat Jahan Procurement Manager Date: _____	Engr. Mahmudul Hasan Head of Procurement Date: _____	A. B. M. Khaled Director (Operations) Date: _____

Signatures are executed on the printed document. The platform does not capture digital signatures.

ITEM COMPARISON SUMMARY — ITEMS 1–8 · TOTALS

SI	Item Description	Specification	Unit	Qty	Dhaka Power Services Ltd.		Eastern Grid Engineering		Rupsha Electromech		Lowest Unit (BDT)
					Unit Price	Total Price	Unit Price	Total Price	Unit Price	Total Price	
1	Transformer oil filtration & degassing	3-pass, on-line	LOT	1	185,000.00	185,000.00	205,000.00	205,000.00	172,000.00	172,000.00	172,000.00
2	Gasket & seal replacement kit	OEM-equivalent	SET	1	68,000.00	68,000.00	74,000.00	74,000.00	60,000.00	60,000.00	60,000.00
3	Bushing inspection & re-torque	HV + LV	LOT	1	55,000.00	55,000.00	60,000.00	60,000.00	52,000.00	52,000.00	52,000.00
4	OLTC servicing	Contacts & diverter oil	LOT	1	120,000.00	120,000.00	128,000.00	128,000.00	118,000.00	118,000.00	118,000.00
5	Oil test suite (BDV / moisture / DGA)	IEC 60422	LOT	1	85,000.00	85,000.00	92,000.00	92,000.00	70,000.00	70,000.00	70,000.00
6	Protection relay secondary injection	All feeders	LOT	1	72,000.00	72,000.00	78,000.00	78,000.00	65,000.00	65,000.00	65,000.00
7	Site labour & shutdown management	—	LOT	1	130,000.00	130,000.00	125,000.00	125,000.00	145,000.00	145,000.00	125,000.00
8	Consumables & incidentals	Lump sum	LOT	1	30,000.00	30,000.00	37,000.00	37,000.00	30,000.00	30,000.00	30,000.00
Sub Total (BDT)					745,000.00		799,000.00		712,000.00		
VAT (15%)					111,750.00		119,850.00		106,800.00		
Grand Total (BDT)					856,750.00		918,850.00		818,800.00		

Lowest quoted unit price per item (arithmetic identification — not a recommendation).

COMMERCIAL COMPARISON SUMMARY

Lowest Grand Total (BDT)	818,800.00
Second Lowest (BDT)	856,750.00
Difference (BDT)	37,950.00
Difference (%)	4.43%

TECHNICAL EVALUATION SUMMARY † buyer-authored

Fully Compliant Vendors	2
Partially Compliant Vendors	1
Non-Compliant Vendors	0

DELIVERY COMPARISON

Shortest Shutdown	2 days — Eastern Grid Engineering
Longest Shutdown	4 days — Rupsha Electromech

PROCUREMENT COMMITTEE APPROVAL

Prepared By	Checked By	Recommended By	Approved By
Md. Asif Hossain Sr. Procurement Executive Date: _____	Nusrat Jahan Procurement Manager Date: _____	Engr. Mahmudul Hasan Head of Procurement Date: _____	A. B. M. Khaled Director (Operations) Date: _____

Signatures are executed on the printed document. The platform does not capture digital signatures.

BUYER EVALUATION SUMMARY † buyer-authored

Order	Vendor	Grand Total (BDT)	Technical	Delivery
1	Dhaka Power Services Ltd.	856,750.00	Fully compliant — IEC 60422	Shutdown window of 3 days
2	Rupsha Electromech	818,800.00	Partially compliant — in-house protocol	Shutdown window of 4 days
3	Eastern Grid Engineering	918,850.00	Fully compliant — IEC 60422	Shutdown window of 2 days

† Evaluation order confirmed by the buyer's procurement team from the computed totals and its own technical assessment. This is the buyer's record — the platform does not rank vendors or recommend a winner.

RECOMMENDATION † buyer-authored

Recommended Vendor	Dhaka Power Services Ltd.
Reason for Recommendation	✓ Full IEC 60422 test-protocol compliance ✓ 12-month warranty on gaskets ✓ 3-day shutdown window within the outage plan ✓ Compliance premium of 4.43% over the lowest offer accepted
Risk Assessment	Low
Commercial Position	BDT 37,950.00 (4.43%) above the lowest offer — premium accepted for IEC 60422 compliance
Remarks	Recommendation reflects the technical assessment, not price order.