ADANGER



Arc Flash and Shock Hazard

Arc Flash Boundary 0.1 ft
Incident Energy (cal/cm²) 0.0
Working Distance 18.0 in

Level A

Shock Hazard Voltage 240 VAC
Limited Approach 3.5 ft
Restricted Approach 1.0 ft

CB23

ADANGER



Arc Flash and Shock Hazard

Arc Flash Boundary
O.1 ft
Incident Energy (cal/cm²)
Working Distance
18.0 in

Level A

Shock Hazard Voltage 240 VAC
Limited Approach 3.5 ft
Restricted Approach 1.0 ft

CB24

ADANGER



Arc Flash and Shock Hazard

Arc Flash Boundary
Incident Energy (cal/cm²)

Working Distance

2.2 ft

2.5

Working Distance

Level B

Shock Hazard Voltage 480 VAC
Limited Approach 3.5 ft
Restricted Approach 1.0 ft

CB4