

**! DANGER**

04-22-2019



### Arc Flash and Shock Hazard

Arc Flash Boundary **0.8 ft**  
Incident Energy (cal/cm<sup>2</sup>) **0.3**  
Working Distance **18.0 in**

**Level A**

Shock Hazard Voltage **480 VAC**  
Limited Approach **3.5 ft**  
Restricted Approach **1.0 ft**

**CB18**

**! DANGER**

04-22-2019



### Arc Flash and Shock Hazard

Arc Flash Boundary **0.8 ft**  
Incident Energy (cal/cm<sup>2</sup>) **0.3**  
Working Distance **18.0 in**

**Level A**

Shock Hazard Voltage **480 VAC**  
Limited Approach **3.5 ft**  
Restricted Approach **1.0 ft**

**CB19**

**! DANGER**

04-22-2019



### Arc Flash and Shock Hazard

Arc Flash Boundary **2.2 ft**  
Incident Energy (cal/cm<sup>2</sup>) **2.5**  
Working Distance **18.0 in**

**Level B**

Shock Hazard Voltage **480 VAC**  
Limited Approach **3.5 ft**  
Restricted Approach **1.0 ft**

**CB2**