

STRATA: A Stratified Process-Mining Framework for HVAC Fault Detection and Diagnosis

Yassh Singh

Supervisors: Dr. Anthony Aighobahi, Dr. Mridula Sharma
Thompson Rivers University — UREAP 2026

September 2026

Abstract

Faults in building HVAC equipment persist because the tools meant to catch them either raise alarms that operators learn to ignore, or flag anomalies that nobody can act on. STRATA turns ordinary one-minute trend data into an event log along the control sequence, discovers process models at the device and unit level, and scores each day through eight calibrated, physically interpretable channels against a measured noise floor, so that every alarm names a location, states its evidence and is held to a false-alarm budget. It was built under a falsification protocol: every hypothesis was pre-registered with the observation that would refute it, every result was recomputed independently before it was quoted, and automated tests pin the published numbers and the falsifiers that fired.

On five public LBNL benchmark systems, including the two fan-powered terminal units for which no detection results had been published before, STRATA detects 158 of 175 seeded faults, most on the first day, at 26 false-alarm days in 480 held-out fault-free days (1 to 9.4% per system). Two systems were onboarded blind, by configuration alone. The alarm names the correct terminal unit in 37 of the 50 detections with known ground truth and a wrong one in none, and the faulted subsystem in 83% of all detections. The false-alarm budget holds under injected sensor error, change-of-value logging and schedule shifts (worst 7 of 96 days) and on one measured rooftop unit (3 of 49).

Process mining helps to get detection but is not detecting on its own. The strata and the event abstraction carry the localisation, and invariants that discovery surfaced became several of the rules that detect. Conformance checking of the discovered models, pre-registered as the detector, was refuted: over 199 scenarios on six systems, no fault is caught by the models alone. A principal-component baseline detects three fewer of the 73 scenarios it shares and cannot name the device. A third-party Guideline 36 rule battery, held to the same gate, matches STRATA within one detection on the air handler and detects a third as many faults on the terminal units, so the pre-registered improvement claim over current practice is withdrawn there. The evaluation also produced eight machine-verified errata in the benchmark datasets. Every number regenerates from the public repository.

1 Introduction

Buildings and construction account for 32% of global final energy use and 34% of energy-related carbon dioxide emissions [41]. HVAC accounts for up to half of an individual building’s consumption [5] and for about 30% of all commercial building energy in the United States [16], and 15–30% of that is wasted through faulty operation and poor control [5,21]; correcting the common faults saves 5–30% of whole-building energy [5,36]. The faults persist even where detection is installed. Across

60,000 pieces of equipment in 317 commercial buildings, Crowe and colleagues found 245 faults per building per month and 40% of air handlers in a faulted state on any given day, in buildings that run modern automation systems with alarms [9]. Seven of their ten most common faults are behaviour-based: wrong schedules, unreleased overrides, missed setpoint resets, broken economiser sequences. A threshold alarm or a pre-written rule [38] catches such a fault only if someone wrote that rule in advance [19]. The public benchmarks used in this paper seed component, sensor and control-loop faults and none of that class, so this argument motivates the design and is not tested by it.

Research has gone the other way. Machine learning has been surveyed across 211 HVAC fault-detection studies [5], with accuracies saturated at 97–99% on the standard benchmarks [35, 40] and interpretability added afterwards at the level of input features [8, 12, 23, 47, 48], which tells an operator that a sensor mattered, not what the building should have been doing. Of 65 primary studies audited in 2025, two shared code links, one of them broken, and 72% do not say whether their data is public [29].

What an operator needs is a detector that works from the trend data already recorded, names the unit and subsystem, explains the alarm in the physics of the equipment, is held to a false-alarm rate measured on the building’s own fault-free days, and reaches a new building by configuration rather than new code. Process mining, the one methodology built to model the sequence in which a system moves between states, has not been brought to this problem: to our knowledge no published work applies event-log process mining to building HVAC fault detection. The 211-study survey contains no process-mining entry [5], the reviews of process mining in Industry 4.0 and on sensor data contain no building HVAC application [2, 6], the Lawrence Berkeley National Laboratory taxonomy of fault-detection methods has no such leaf [18], and our own exact-phrase searches of the OpenAlex corpus return none [34].

STRATA applies process mining in stratified form: sensor streams are abstracted into events along ASHRAE Guideline 36 control sequences [3], Petri nets are discovered per device and per unit [30, 42], and the channels that read the log sit beside physics rules and residuals that read the raw signals, each calibrated on its own noise. Our first hypothesis, that the discovered net would itself be the detector, was pre-registered and refuted: a single hand-written rule out-covered the model channel where it was strongest. What settled is the division of labour, and it is a productive one. The strata and the event abstraction give every alarm its location, the frequency and oscillation channels are the only ones that catch the unstable-controller faults, invariants that discovery surfaced became several of the rules that detect, and conformance checking of the discovered nets, the part we expected to detect, contributes no detection of its own. Process mining helps to get detection but is not detecting on its own.

The paper contributes (1) the framework and the detector it yields, evaluated on five public benchmark systems including the two fan-powered terminal units for which no detection results had been published before; (2) what process mining contributes to HVAC fault detection, established under pre-registration: the first such application, whose structure gives the detector its location and several of its rules, and whose conformance channel catches no fault the calibrated channels miss; (3) an evaluation protocol of pre-registration, honoured falsifiers, independent recomputation and full artefact regeneration; and (4) eight machine-verified errata in the benchmark datasets.

2 Research Aim and Objectives

This research set out to build a fault detector for building HVAC systems that an operator can trust and act on: one that works from the trend data the building already records, explains each

alarm in the physics of the equipment, names the unit and the subsystem at fault, is held to a false-alarm rate measured on the building’s own fault-free days, and reaches a new building by configuration rather than new code. Process mining was the means chosen to get there, because it is the one methodology built to model the sequence in which a system moves between states, and no published work had applied it to this problem. The aim therefore carried a second question: what the discovered process models contribute to such a detector, and whether they detect on their own. Everything reported here is validated on public benchmark data; deployment on an operating building is the intended next phase, and Section ?? states what it would take.

A building operator today finds a fault by waiting for a complaint or by watching trend graphs for a curve that has drifted from where it usually sits; both find it late and neither names the equipment responsible. STRATA is meant to consume a building’s ordinary one-minute trend data and one configuration file naming its sensors and control rules, learn from a fault-free period what healthy operation looks like, and then, every day, name the days that break a physical relationship the healthy period established: which unit, which relationship, by how much, and how often that channel has cried wolf on healthy days. The output is a work order with a false-alarm budget the operator can hold the system to, and onboarding a new equipment type is a configuration exercise. That intent fixes six objectives, each reported with what was done and where it stands.

1. Abstract events from sensor data along Guideline 36 control sequences, with fault-signature events held out of model discovery. Each day is a case and every event is emitted by a configured rule: three kinds produce the state events model discovery may see, five produce fault-signature events it may not. The same code, with no building-specific additions, ran on seven LBNL datasets; the alphabet wall is enforced by unit tests and the circularity it prevents was measured. Met.
2. Discover models and establish what they contribute. Nets discovered at device, unit and cross-system strata on every system; their contribution measured under pre-registration on 199 scenarios across six systems. Met: the structure, the event log and the invariants they surfaced are what they contribute; the hypothesis that they would also detect by conformance alone is refuted.
3. Detect against a measured noise floor. Eight channels, every threshold from the fault-free year, every false-alarm rate out-of-sample; the budget held under injected field conditions and on one measured building. Met; the statistical repair that made this true cost seven detections, and that is stated.
4. Benchmark against known answers. 158 of 175 seeded scenarios detected at 26 false-alarm days in 480; against an audited PCA baseline, 64 of 73 to its 61; against the open-fdd Guideline 36 battery held to the same gate, within one detection on the air handler and three times the detections on the terminal units. All three parts executed; the improvement claim over current practice is withdrawn on the air handler.
5. Make every claim checkable. More than thirty pre-registered experiments, ten adverse results and four later fired falsifiers published, every headline number regenerated under a regression gate, a test suite that fails if a caveat is dropped. Met.
6. Release the work openly. Repository, configurations, artefacts, reproduction path and eight machine-verified dataset errata are public. Met.

What the objectives add up to is a detector that does what the intent asks on the benchmarks it was tested on, a measured and stated answer to the process-mining question, and a protocol that

made both checkable. What they do not yet add up to is a field result; Section ?? states what that would take. A hybrid with machine-learning classifiers was deferred until the models’ own detection had been established, and is future work.

3 Related Work

Machine learning for HVAC fault detection. Bi and colleagues survey 211 AI-based HVAC fault-detection studies from 2013 to 2023 [5]. Accuracies on the standard benchmarks have saturated: 98% across thirteen fault types with a random-forest and support-vector pipeline on RP-1312 data [40], 97% on three real buildings with a convolutional-and-LSTM hybrid whose authors name interpretability as the problem they did not solve [35]. The interpretable line pairs a deep model with a post-hoc explanation: Deng and colleagues’ graph network on the LBNL single-duct data reaches 88% at 500 labelled samples with per-sensor importance as the explanation [12]; attention and relevance propagation do the same on chiller data [8,23,47,48]. The explanation is at the level of input features, not of the control sequence the building was supposed to follow. The opportunity is a method whose model is its explanation.

Unsupervised methods and cross-building transfer. Real buildings rarely carry fault labels, so the strongest recent work is self-supervised: a masked-reconstruction Transformer on an unlabelled heat-pump building [1], and El Mokhtari and McArthur’s autoencoders across five fan coil units at Toronto Metropolitan University, the closest precedent for a Canadian university deployment [13]. Each yields a scalar anomaly score. Cross-building transfer in this literature means transferring learned weights by domain adaptation [14,15,22,50]; what STRATA transfers is a configuration file naming sensors and rules, a different operation, and the discovered models themselves did not transfer (Section ??).

Process mining and the empty quadrant. Process mining discovers models from event logs, checks conformance against them and enhances them with further perspectives [42,43]. Conformance was used directly as a trace-level anomaly detector [4,37] before neural sequence models overtook it on standard log corpora [32]; our own ablation, which finds no fault detected only by conformance, is consistent with that motivation. In adjacent cyber-physical domains the methodology has succeeded: robotic-arm fault diagnosis at an F1 of 98.9% [45], with alignment features feeding downstream classifiers for gains of 30 to 70 F1 points [46]; industrial IoT sensor validation [20]; industrial control systems [31,39]; and pasteurisation, where continuous sensor signals are abstracted into activity sequences and checked against a process specification [28]. The common barrier is event abstraction [7,10,26]. Building HVAC is an empty quadrant: the 211-study survey has no process-mining entry [5], the 47-study Industry 4.0 review [2] and the 36-study sensor-data review [6] contain no building HVAC application, construction-management process mining treats projects as cases and human tasks as activities [27], LBNL’s fault-detection taxonomy has no such leaf [18], and exact-phrase searches of OpenAlex [34] and the ICPM 2025 programme return none.

Rule-based practice. Fault detection in real buildings is rule-based: commercial platforms such as Automated Logic WebCTRL, installed at the Campus Activity Centre of Thompson Rivers University, ship libraries of over one hundred named faults, and Granderson and colleagues’ survey of fourteen commercial tools confirms the style [18,33]. LBNL’s automated fault-correction line applies hand-coded correction algorithms through BACnet writeback [24,25,36]. Both assume the faults of interest can be enumerated in advance. STRATA is complementary: it learns where

the building’s own healthy operation is invariant and holds those invariants at a measured false-alarm budget, and its located, evidenced alarms could in principle feed the correction algorithms. Section ?? measures both the strength and the limit of the rule library on the same benchmarks. Hand-designed Petri nets for HVAC [11, 17, 44, 49] are a different use of the formalism: authored by an engineer, with no event log and no discovery, and should not be conflated with the discovered models used here.

References

- [1] Mohammad Amin Fatemi Abdollah, Rossano Scoccia, and Marcello Aprile. Transformer encoder based self-supervised learning for HVAC fault detection with unlabeled data. *Building and Environment*, 258:111568, 2024.
- [2] Katsiaryna Akhramovich, Estefanía Serral, and Carlos Cetina. A systematic literature review on the application of process mining to Industry 4.0. *Knowledge and Information Systems*, 66(5):2699–2746, 2024.
- [3] ASHRAE. ASHRAE Guideline 36-2021: High-performance sequences of operation for HVAC systems. American Society of Heating, Refrigerating and Air-Conditioning Engineers, Peachtree Corners, GA, 2021.
- [4] Fábio Bezerra and Jacques Wainer. Algorithms for anomaly detection of traces in logs of process aware information systems. *Information Systems*, 38(1):33–44, 2013.
- [5] Jian Bi, Hua Wang, Enbo Yan, Chuan Wang, Ke Yan, Liangliang Jiang, and Bin Yang. AI in HVAC fault detection and diagnosis: A systematic review. *Energy Reviews*, 3(2):100071, 2024.
- [6] Edyta Brzychczy, Milda Aleknonytė-Resch, Dominik Janssen, and Agnes Koschmider. Process mining on sensor data: a review of related works. *Knowledge and Information Systems*, 67:4915–4948, 2025.
- [7] Edyta Brzychczy, Urszula Jessen, Krzysztof Kluza, Sridhar Sriram, and Manuel Vargas Netteknot. IoT Miner: Intelligent extraction of event logs from sensor data for process mining. *arXiv preprint arXiv:2509.05769*, 2025. Preprint; verified 2026-09-29.
- [8] Zhe Chen, Fu Xiao, Fangzhou Guo, and Jinyue Yan. Interpretable machine learning for building energy management: A state-of-the-art review. *Advances in Applied Energy*, 9:100123, 2023.
- [9] Eliot Crowe, Yimin Chen, Hayden Reeve, David Yuill, Amir Ebrahimifakhar, Yuxuan Chen, Lucas Troup, Amanda Smith, and Jessica Granderson. Empirical analysis of the prevalence of HVAC faults in commercial buildings. *Science and Technology for the Built Environment*, 29(10):1027–1038, 2023.
- [10] Francesca De Luzi, Francesco Leotta, Andrea Marrella, and Massimo Mecella. On the interplay between business process management and Internet-of-Things: A systematic literature review. *Business & Information Systems Engineering*, 67(2):265–288, 2025.
- [11] Wael Deabes, Kheir Eddine Bouazza, and Wasl Alghami. Smart fuzzy Petri net-based temperature control framework for reducing building energy consumption. *Sensors*, 23(13):5985, 2023.

- [12] Qiao Deng, Zhiwen Chen, Wanting Zhu, Zefan Li, Yifeng Yuan, and Yalin Wang. Adaptive fusion graph convolutional network based interpretable fault diagnosis method for HVAC systems enhanced by unlabeled data. *Energy and Buildings*, 324:114901, 2024.
- [13] Karim El Mokhtari and J. J. McArthur. Autoencoder-based fault detection using building automation system data. *Advanced Engineering Informatics*, 62:102810, 2024.
- [14] Bowei Feng, Qizhen Zhou, Jianchun Xing, Qiliang Yang, Yin Chen, and Zhongkai Deng. Attention-empowered transfer learning method for HVAC sensor fault diagnosis in dynamic building environments. *Building and Environment*, 250:111148, 2024.
- [15] Naghmeh Ghalamsiah, Jin Wen, K. Selcuk Candan, Teresa Wu, Zheng O’Neill, and Asra Aghaei. Unsupervised domain adaptation for HVAC fault diagnosis using contrastive adaptation network. *Energy and Buildings*, 337:115659, 2025.
- [16] William Goetzler, Richard Shandross, Jim Young, Oxana Petritchenko, Decker Ringo, and Sam McClive. Energy savings potential and RD&D opportunities for commercial building HVAC systems. Report DOE/EE-1703, U.S. Department of Energy, Office of Energy Efficiency and Renewable Energy, Building Technologies Office, December 2017. Prepared by Navigant Consulting, Inc.
- [17] Luís Gomes, Anikó Costa, João Paulo Barros, Rui Pais, Tiago Rodrigues, and Richard Ferreira. Petri net based building automation and monitoring system. In 2007 5th IEEE International Conference on Industrial Informatics (INDIN), pages 57–62, 2007.
- [18] Jessica Granderson, Rupam Singla, Ebony Mayhorn, Paul Ehrlich, Draguna Vrabie, and Stephen Frank. Characterization and survey of automated fault detection and diagnostic tools. Technical Report LBNL-2001075, Lawrence Berkeley National Laboratory, Berkeley, CA, November 2017.
- [19] H. Burak Gunay, Jayson Bursill, Brent Huchuk, and Scott Shillinglaw. Inverse model-based detection of programming logic faults in multiple zone VAV AHU systems. *Building and Environment*, 211:108732, 2022.
- [20] Erik Johannes Husom, Arda Goknil, Felix Mannhardt, Simeon Tverdal, Sagar Sen, and Phu Nguyen. Unsupervised learning and process analysis for sensor data validation in the IIoT. *ACM Transactions on Internet Technology*, 26(2):1–34, 2026.
- [21] Srinivas Katipamula and Michael R. Brambley. Methods for fault detection, diagnostics, and prognostics for building systems—a review, part I. *HVAC&R Research*, 11(1):3–25, 2005.
- [22] Yutian Lei, Cheng Fan, Haihui He, and Yonghang Xie. Enabling efficient cross-building HVAC fault inferences through novel unsupervised domain adaptation methods. *Building and Environment*, 272:112678, 2025.
- [23] Guannan Li, Luhan Wang, Limei Shen, Liang Chen, Hengda Cheng, Chengliang Xu, and Fan Li. Interpretation of convolutional neural network-based building HVAC fault diagnosis model using improved layer-wise relevance propagation. *Energy and Buildings*, 286:112949, 2023.
- [24] Guanqing Lin, Marco Pritoni, Yimin Chen, and Jessica Granderson. Development and implementation of fault-correction algorithms in fault detection and diagnostics tools. *Energies*, 13(10):2598, 2020.

- [25] Guanqing Lin, Marco Pritoni, Yimin Chen, Raphael Vitti, Christopher Weyandt, and Jessica Granderson. Implementation and test of an automated control hunting fault correction algorithm in a fault detection and diagnostics tool. *Energy and Buildings*, 283:112796, 2023.
- [26] Juergen Mangler, Ronny Seiger, Janik-Vasily Benzin, Joscha Grüger, Yusuf Kirikkayis, Florian Gallik, Lukas Malburg, Matthias Ehrendorfer, Yannis Bertrand, Marco Franceschetti, Barbara Weber, Stefanie Rinderle-Ma, Ralph Bergmann, Estefanía Serral Asensio, and Manfred Reichert. From Internet of Things data to business processes: Challenges and a framework. *arXiv:2405.08528*, 2024.
- [27] Araham Jesus Martinez Lagunas and Mazdak Nik-Bakht. Process mining, modeling, and management in construction: A critical review of three decades of research coupled with a current industry perspective. *Journal of Construction Engineering and Management*, 150(11):04024158, 2024.
- [28] Azin Moradbeikie, Ana Paula Ayub da Costa Barbon, Iuliana Malina Grigore, Douglas Fernandes Barbin, and Sylvio Barbon Junior. Process mining of sensor data for predictive process monitoring: A HACCP-guided pasteurization study case. *Systems*, 13(11):935, 2025.
- [29] Adil Mukhtar, Michael Hadwiger, Franz Wotawa, and Gerald Schweiger. Reproducibility of machine learning-based fault detection and diagnosis for HVAC systems in buildings: An empirical study. *Energy and AI*, 22:100658, 2025. Also *arXiv:2508.00880*.
- [30] Tadao Murata. Petri nets: Properties, analysis and applications. *Proceedings of the IEEE*, 77(4):541–580, 1989.
- [31] David Myers, Suriadi Suriadi, Kenneth Radke, and Ernest Foo. Anomaly detection for industrial control systems using process mining. *Computers & Security*, 78:103–125, 2018.
- [32] Timo Nolle, Stefan Luettggen, Alexander Seeliger, and Max Mühlhäuser. BINet: Multi-perspective business process anomaly classification. *Information Systems*, 103:101458, 2022.
- [33] Ojas Pradhan, Jin Wen, Yimin Chen, Xing Lu, Mengyuan Chu, Yangyang Fu, Zheng O’Neill, Teresa Wu, and K. Selçuk Candan. Dynamic Bayesian network-based fault diagnosis for ASHRAE Guideline 36. In *Proceedings of the 8th ACM International Conference on Systems for Energy-Efficient Buildings, Cities, and Transportation (BuildSys ’21)*, pages 365–368. ACM, 2021.
- [34] Jason Priem, Heather Piwowar, and Richard Orr. OpenAlex: A fully-open index of scholarly works, authors, venues, institutions, and concepts. *arXiv:2205.01833*, 2022.
- [35] Prince, Byungun Yoon, and Prashant Kumar. Fault detection and diagnosis in air-handling unit (AHU) using improved hybrid 1D convolutional neural network. *Systems*, 13(5):330, 2025.
- [36] Marco Pritoni, Guanqing Lin, Yimin Chen, Raphael Vitti, Christopher Weyandt, and Jessica Granderson. From fault-detection to automated fault correction: A field study. *Building and Environment*, 214:108900, 2022.
- [37] Anne Rozinat and Wil M. P. van der Aalst. Conformance checking of processes based on monitoring real behavior. *Information Systems*, 33(1):64–95, 2008.
- [38] Jeffrey Schein, Steven T. Bushby, Natascha S. Castro, and John M. House. A rule-based fault detection method for air handling units. *Energy and Buildings*, 38(12):1485–1492, 2006.

- [39] Prasannjeet Singh, Mehdi Saman Azari, Francesco Vitale, Francesco Flammini, Nicola Mazzocca, Mauro Caporuscio, and Johan Thornadtsson. Using log analytics and process mining to enable self-healing in the Internet of Things. *Environment Systems and Decisions*, 42:234–250, 2022.
- [40] Wunna Tun, Johnny Kwok-Wai Wong, and Sai-Ho Ling. Hybrid random forest and support vector machine modeling for HVAC fault detection and diagnosis. *Sensors*, 21(24):8163, 2021.
- [41] United Nations Environment Programme and Global Alliance for Buildings and Construction. Global status report for buildings and construction 2024/2025: Not just another brick in the wall. Technical report, United Nations Environment Programme, Nairobi, 2025. Buildings and construction: 32 % of global final energy use and 34 % of energy-related CO₂ emissions in 2023.
- [42] Wil M. P. van der Aalst. *Process Mining: Data Science in Action*. Springer, 2nd edition, 2016.
- [43] Wil M. P. van der Aalst, Arya Adriansyah, Ana Karla Alves de Medeiros, Franco Arcieri, Thomas Baier, Tobias Blickle, Jagadeesh Chandra Bose, Peter van den Brand, Ronald Brandtjen, Joos Buijs, et al. Process mining manifesto. In *Business Process Management Workshops (BPM 2011)*, volume 99 of *Lecture Notes in Business Information Processing*, pages 169–194. Springer, 2012.
- [44] Emilia Villani and Paulo E. Miyagi. A hybrid Petri net modeling approach for HVAC systems in intelligent buildings. *SBA: Controle & Automação*, 15(2):135–148, 2004.
- [45] Francesco Vitale, Nicola Dall’Ora, Sebastiano Gaiardelli, Enrico Fraccaroli, Nicola Mazzocca, and Franco Fummi. Process mining-driven modeling and simulation to enhance fault diagnosis in cyber-physical systems. *Journal of Manufacturing Systems*, 84:189–206, 2026. Also arXiv:2506.21502 (2025).
- [46] Francesco Vitale, Marco Pegoraro, Wil M. P. van der Aalst, and Nicola Mazzocca. Control-flow anomaly detection by process mining-based feature extraction and dimensionality reduction. *Knowledge-Based Systems*, 310:112970, 2025.
- [47] Hong Wang, Wenjing Yan, Yajuan Zhang, Jianqiang Yu, Wensheng Gao, Bowen Zhou, and Yi Liu. xMHAC-PDCNN: An explainable deep network with spatial feature embedding for fault detection and diagnosis of chillers under variable operating conditions. *Building and Environment*, 284:113504, 2025.
- [48] Chenglong Xiong, Guannan Li, Ying Yan, Hanyuan Zhang, Chengliang Xu, and Liang Chen. Effects of various information scenarios on layer-wise relevance propagation-based interpretable convolutional neural networks for air handling unit fault diagnosis. *Building Simulation*, 17(10):1709–1730, 2024.
- [49] Bing Xu, Jun Su, Qiu Min Fan, and Ya Cheng Zhu. Wireless sensors system for the chillers fault diagnostic based on characteristic Petri net modelling. *International Journal of Wireless and Mobile Computing*, 9(1):43–48, 2015.
- [50] Xu Zhu, Kang Chen, Burkay Anduv, Xinqiao Jin, and Zhimin Du. Transfer learning based methodology for migration and application of fault detection and diagnosis between building chillers for improving energy efficiency. *Building and Environment*, 200:107957, 2021.