Aurora Lake Water Quality Report

The Aurora Lake Water Authority publishes this report every quarter.

Turbidity

Average turbidity in the third quarter was 0.37 NTU, below the 1.0 NTU limit.

The highest single reading was 0.82 NTU on 14 August after heavy rain.

Maintenance

Crews replaced 12 membrane modules at the Eastside plant in September.

Filtration uptime was 98.6 percent for the quarter.