

444 South 16th Street Mall Omaha, NE 68102-2247

LIC-13-0057 May 3, 2013

U.S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555-0001

Reference: Docket No. 50-285

Subject:

Licensee Event Report 2013-006, Revision 0, for the Fort Calhoun

Station

Please find attached Licensee Event Report 2013-006, Revision 0, dated May 3, 2013. This report is being submitted pursuant to 10 CFR 50.73(a)(2)(ii)(B), 10 CFR 50.73(a)(2)(v)(B) and (D), and 10 CFR 50.73(a)(2)(vii). There are no new commitments being made in this letter.

If you should have any questions, please contact Terrence W. Simpkin, Manager, Site Regulatory Assurance, at (402) 533-6263.

Sincerely,

Louis P. Cortopassi

Site Vice President and CNO

LPC/epm/rjr

Attachment

A. T. Howell, NRC Regional Administrator, Region IV

J. M. Sebrosky, NRC Project Manager

L. E. Wilkins, NRC Project Manager

J. C. Kirkland, NRC Senior Resident Inspector

NRC FO	RM 366		U.S. NUCLEAR REGULATORY COMMISSION						APPROVED BY OMB: NO. 3150-0104 EXPIRES: 10/31						/31/2013			
(10-2010) LICENSEE EVENT REPORT (LER) (See reverse for required number of digits/characters for each block)										Estimated burden per response to comply with this mandatory collection request: 80 hours. Reported lessons learned are inco rporated into the licensing process and fed back to industry. Send comments regarding burden estimate to the FOIA/Priv acy Section (T-5 F53), U.S. Nuclear Regulator y Commission, Washington, DC 205 55-0001, or b y internet e-mail to infocollects.resource@nrc.gov, and to the Desk Officer, Office of Information and Regulatory Affairs, NEOB-10202, (3150-0104), Office of Management and Budget, Washington, DC 20503. If a means used to impose an information collection does not display a currently valid OMB control number, the NRC may not conduct or sp onsor, and a person is not required to respond to, the information collection.								
1. FACILITY NAME 2 Fort Calhoun Station										2. DOCKET NUMBER 3. PAGE 05000285 1 OF 3								
4. TITLE			1 011 0			on in LP	SI and (CS Pum	ір Ме	echanical Se	als		•	<u> </u>	<u> </u>			
5. EVENT DATE 6. LER NUMBER 7. REPORT DATE											8. OTHER FACILITIES INVOLVED							
MONTH DAY YEAR			YEAR SEQUENTIAL REV NUMBER NO.			MONTH			FACILITY NAME			AGILITI	DOCKET NUMBER 05000					
03	04	2013	2013	006	- 0	05	03	2013	FACIL	LITY NAME			DOCKET NUME 0500					
9. OPER	ATING	MODE	11.	THIS REP	ORT IS	SUBMITTE	D PURSI	JANT TO	THE	REQUIREMEN	TS OF	10 CFR	§: (Check	all tha	at apı	oly)		
5 10. POWER LEVEL 0			□ 20.2201(b) □ 20.2203(a)(3)(i) □ 20.2201(d) □ 20.2203(a)(3)(ii) □ 20.2203(a)(1) □ 20.2203(a)(4) □ 20.2203(a)(2)(i) □ 50.36(c)(1)(i)(A) □ 20.2203(a)(2)(ii) □ 50.36(c)(1)(ii)(A) □ 20.2203(a)(2)(iii) □ 50.36(c)(2) □ 20.2203(a)(2)(iv) □ 50.46(a)(3)(ii) □ 20.2203(a)(2)(v) □ 50.73(a)(2)(i)(A) □ 20.2203(a)(2)(vi) □ 50.73(a)(2)(i)(B)					(3)(ii) (4) (i)(A) (ii)(A) (ii)(A) (iii) (ii)(A)	□ 50.73(a)(2)(i)(C) □ 50.73(a)(2)(vii) □ 50.73(a)(2)(ii)(A) □ 50.73(a)(2)(viii)(A) □ 50.73(a)(2)(iii)(B) □ 50.73(a)(2)(viii)(B) □ 50.73(a)(2)(iii) □ 50.73(a)(2)(ix)(A) □ 50.73(a)(2)(iv)(A) □ 50.73(a)(2)(x) □ 50.73(a)(2)(v)(A) □ 73.71(a)(4) □ 50.73(a)(2)(v)(B) □ 73.71(a)(5) □ 50.73(a)(2)(v)(C) □ OTHER □ 50.73(a)(2)(v)(D) Specify in Abstract below or in NRC Form 366A									
					1	2. LICENS	SEE CON	TACT FO	R THI	S LER								
FACILITY NAME 12. LICENSEE CONTACT FOR THIS LER TELEPHONE NUMBER (Include Area Code) 402-533-6855																		
			13. COM	IPLETE ON	E LINE I	OR EAC	1 COMPO	NENT FA	AILUR	E DESCRIBED	IN TH	IS REPC	RT					
CAUSE		SYSTEM	1 COM	MPONENT	MANU FACTUR		ORTABLE O EPIX	CAU	USE SYSTEM COMPONENT		PONENT	MANU- FACTURE						
14			I. SUPPLEMENTAL REPORT EXPECTED						15. EXPECTED SUBMISSION				MONTH	DA	Y	YEAR		
⊠YE	S (If yes	, complete	te 15. EXPECTED SUBMISSION DATE)						NO		ISSIOI ATE	N	8	9		13		
ABSTRA	CT (Lin	it to 1400	spaces.	i.e., approx	matelv 1	5 sinale-sı	paced type	ewritten lii	nes)									
On March 04, 2013, at approximately 1400 CST, it was identified that the mechanical seals used in the two low pressure safety injection pumps and the three containment spray pumps are made of a material (Teflon®) that may not maintain the designed integrity of the systems under certain accident conditions. This seal design has been installed since original plant construction. This issue was discovered while the core was off-loaded by plant personnel while researching requirements for the replacement parts during scheduled outage activities. A causal analysis is in progress. The results of the analysis will be published in a supplement to this LER.																		

(10-2010)

LICENSEE EVENT REPORT (LER) U. CONTINUATION SHEET

2)	U.S. NUCLEAR REGULATORY COMMISSION
()	

1. FACILITY NAME	2. DOCKET	6	. LER NUMBER	3. PAGE			
Fort Calhoun Station	05000285	YEAR	SEQUENTIAL NUMBER	REV NO.	•	OF	3
Fort Calhoun Station		2013	- 006 -	0	2		

NARRATIVE

BACKGROUND

Fort Calhoun Station (FCS) is a two-loop reactor coolant system of Combustion Engineering (CE) design. The three containment spray (CS) and two low pressure safety injection (LPSI) pumps are part of the safety injection system. The CS and LPSI pumps are located outside of containment.

USAR Section 1.2.5, Engineered Safeguards Systems, contains the following information.

The CS system supplies borated water to cool and reduce the pressure of the containment atmosphere following a main steam line break. The pumps take suction from the safety injection and refueling water storage tank (SIRWT). Following a loss of coolant accident (LOCA), during the recirculation mode, the system can be aligned to the suction of the high pressure safety injection pumps (HPSI) to provide a source of subcooled water to supplement long term core cooling.

USAR Section 6.2, Safety Injection System, 6.2.1 Design Bases, states the following.

For a design basis large break LOCA, both the HPSI and LPSI pumps will operate for accident mitigation. For a main steam line break (MSLB) the HPSI, LPSI, and CS pumps will operate.

USAR Section 6.2.3.2, Low-Pressure Safety Injection Pumps, states the following.

The low-pressure safety injection pumps are used to inject large quantities of borated water into the reactor coolant system. They are also used to circulate reactor coolant during shutdown to remove residual and decay heat.

USAR Section 6.3, Containment Spray System, 6.3.1 Design Bases states the following.

The function of the containment spray system is to limit the containment pressure rise by providing a means for cooling the containment following a Main Steam Line Break (MSLB). The containment spray system may also function to augment long term core cooling for LOCA during the recirculation mode of operation.

EVENT DESCRIPTION

On March 04, 2013, at approximately 1400 CST, it was identified that the mechanical seals used in the two low pressure safety injection pumps and the three containment spray pumps are made of a material (Teflon®) that may not maintain the designed integrity of the systems under certain accident conditions. This seal design has been installed since original plant construction. This issue was discovered while the core was off-loaded by plant personnel while researching requirements for the replacement parts during scheduled outage activities.

A causal analysis is in progress. The results of the analysis will be published in a supplement to this LER.

This report is being submitted pursuant to 50.73(a)(2)(ii)(B) Any event or condition that resulted in the nuclear power plant being in an unanalyzed condition that significantly degraded plant safety, 10 CFR 50.73(a)(2)(v) Any event or condition that could have prevented the fulfillment of the safety function of structures or systems that are needed to (B) Remove residual heat, and (D) Mitigate the consequences of an accident, and 10 CFR 50.73(a)(2)(vii) Any event where a single cause or condition caused at least one independent train or channel to become inoperable in multiple systems or two independent trains or channels to become inoperable in a single system designed to (B)

NRC FORM 366A

(10-2010)

LICENSEE EVENT REPORT (LER) U.S. NUCLEAR REGULATORY COMMISSION CONTINUATION SHEET

1. FACILITY NAME	2. DOCKET	6	6. LER NUMBER	3. PAGE			
Fort Callbour Station	05000285	YEAR	SEQUENTIAL NUMBER	REV NO.	0	OF	3
Fort Calhoun Station		2013	- 006 -	0	3		

NARRATIVE

Remove residual heat and (D) Mitigate the consequences of an accident." This condition was initially reported on March 4, 2013 under 10 CFR 50.72(b)(3)(ii)(B), Unanalyzed Condition (ENS No. 48806).

CONCLUSION

A causal analysis is in progress. The results of the analysis will be published in a supplement to this LER.

CORRECTIVE ACTIONS

A causal analysis is in progress. The results of the analysis will be published in a supplement to this LER

SAFETY SIGNIFICANCE

A causal analysis is in progress. The results of the analysis will be published in a supplement to this LER.

SAFETY SYSTEM FUNCTIONAL FAILURE

A causal analysis is in progress. The results of the analysis will be published in a supplement to this LER.

PREVIOUS EVENTS

A causal analysis is in progress. The results of the analysis will be published in a supplement to this LER.