



Omaha Public Power District

444 South 16th Street Mall

Omaha, NE 68102-2247

LIC-12-0182

December 7, 2012

U.S. Nuclear Regulatory Commission

Attn: Document Control Desk

Washington, DC 20555-0001

References: 1. Docket No. 50-285
2. Letter from OPPD (D. J. Bannister) to NRC Document Control Desk (DCD) dated June 25, 2012 (LIC-12-0090)

Subject: Withdrawal of Licensee Event Report 2012-006, Revision 0, for the Fort Calhoun Station

By letter dated June 25, 2012, Omaha Public Power District (OPPD) submitted Licensee Event Report (LER) 2012-006, Revision 0, "Operation of Component Cooling Pumps Outside of the Manufacturers Recommendation," for the Fort Calhoun Station (FCS). Based on additional investigation, the FCS Engineering Department has determined that the flow instrumentation was inaccurate and that the pumps have been operated as designed. As a result, OPPD is withdrawing LER 2012-006 and this number will not be reused.

No commitments are being made in this letter.

If you should have any questions, please contact me.

Sincerely,

Louis P. Cortopassi
Site Vice President and CNO

LPC/EPM

Attachment

c: E. E. Collins, Jr., NRC Regional Administrator, Region IV
L. E. Wilkins, NRC Project Manager
J. C. Kirkland, NRC Senior Resident Inspector