



Entergy Operations, Inc.  
River Bend Station  
5485 U. S. Highway 61N  
St. Francisville, LA 70775  
Tel 225 381 4374  
Fax 225 381 4872  
eolson@entergy.com

Eric W. Olson  
Site Vice President

RBG-47519

December 5, 2014

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Subject: Cancellation of Licensee Event Report  
River Bend Station - Unit 1  
Docket No. 50-458  
License No. NPF-47

RBF1-14-0178

On March 12, 2014, River Bend Station submitted Licensee Event Report (LER) 050-458 / 2014-002-00, Operations Prohibited by Technical Specification for Reactor Pressure / Temperature Limits. Specifically, that report concerned the operational practice of allowing reactor pressure to become negative during plant startups with the main steam isolation valves open to the main condenser. Negative pressure is not bounded by Technical Specification 3.4.11, Reactor Coolant System Pressure and Temperature Limits.

A similar event report was submitted on March 4, 2014 by the Perry Nuclear Power Plant. That plant was also cited for having violated their Technical Specifications. In a subsequent letter from A. T. Boland to E. J. Harkness (letter ML14246A151, dated September 3, 2014), NRC concluded that no violation of TS 3.4.11 had actually occurred. The Perry plant has since cancelled that LER.

By virtue of that precedence, River Bend Station hereby cancels LER 050-458 / 2014-002-00.

This letter contains no commitments. Please contact Mr. Joey Clark at 225-381-4177 if there are any questions.

Sincerely,

EWO/dhw

cc: U. S. Nuclear Regulatory Commission  
Region IV  
1600 East Lamar Blvd.  
Arlington, TX 76011-4511

LE22  
NRR



Cancellation of Licensee Event Report  
December 5, 2014  
RBG-47519  
Page 2 of 2

NRC Sr. Resident Inspector  
P. O. Box 1050  
St. Francisville, LA 70775

INPO  
(via ICES reporting)

Central Records Clerk  
Public Utility Commission of Texas  
1701 N. Congress Ave.  
Austin, TX 78711-3326

Department of Environmental Quality  
Office of Environmental Compliance  
Radiological Emergency Planning and Response Section  
Ji Young Wiley  
P.O. Box 4312  
Baton Rouge, LA 70821-4312