



444 South 16<sup>th</sup> Street Mall  
Omaha, NE 68102-2247

August 4, 2010  
LIC-10-0054

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

References: 1. Docket No. 50-285  
2. Letter from OPPD (R. A. Reinhart) to NRC (Document Control Desk), dated August 10, 2009 (LIC-09-0053)

**Subject: Cancellation of Licensee Event Report 2009-003 for the Fort Calhoun Station**

This letter constitutes notification to the NRC of the cancellation of Fort Calhoun's Licensee Event Report (LER) 2009-003, "Void in Safety Injection Piping During Operation Due to Inadequate Procedural Guidance."

A detailed analysis was performed on the effect of the void on the safety injection system. The analysis concludes that the void will pass through the safety injection pump with little or no affect on the operation of the pump and that no water hammer affects would be induced. Based on these results it is concluded that the pump and piping would perform their intended safety function and would not be affected by the void. Therefore, the condition was not reportable.

If you should have any questions, please contact me.

Sincerely,

Jeffrey A. Reinhart  
Site Vice President

JAR/EPM

c: E. E. Collins, NRC Regional Administrator, Region IV  
L. E. Wilkins, NRC Project Manager  
J. C. Kirkland, NRC Senior Resident Inspector  
INPO Records Center

**Employment with Equal Opportunity**

JE22  
NRC