TENDER FOR SUPPLY AND LAYING OF uPVC PRESSURE PIPES FOR WATER SUPPLY

Tender Reference No: SISAP/DEMO/WTR-2026/03

Issuing Authority: Urban Water Supply Board (demonstration document)

1. SCOPE OF WORK

1.1 Supply, laying, jointing, testing and commissioning of unplasticized polyvinyl chloride (uPVC) pressure pipes for a potable water distribution network.

2. TECHNICAL SPECIFICATION

2.1 Pipes shall be unplasticized PVC pressure pipes of the pressure class stated in the bill of quantities, suitable for potable water.

2.2 Pipes shall be supplied in standard lengths with spigot and socket ends suitable for solvent cement jointing.

2.3 The hydrostatic design stress of the pipe material shall be adequate for the design working pressure with an appropriate factor of safety.

3. INSTALLATION

3.1 Pipes shall be laid in a prepared trench on a bed of approved material with a minimum cover as specified in the applicable code of practice for laying of service pipes.

3.2 Thrust blocks shall be provided at all bends, tees and valves.

3.3 The pipeline shall be snaked slightly in the trench to accommodate thermal movement.

4. TESTING

4.1 The laid pipeline shall be subjected to a hydrostatic pressure test before being charged.

4.2 The pipeline shall be disinfected and flushed before being put into service.

5. SAFETY

5.1 Trench excavation shall be properly supported and barricaded.

5.2 Workers shall be provided with safety helmets, safety shoes and high visibility clothing.