

Nephrova Renal Care Pvt. Ltd.

Generator Service and Load Test Report

Equipment: GEN-P1 (125 kVA diesel generator, Nephrova Pimpri). Date: 8 September 2026. Engineer: Nikhil Joshi.

Complaint

GEN-P1 took 45 seconds to start during the mains outage of 7 September 2026.

Finding

The starter battery of GEN-P1 was weak (11.2 V under cranking load).

Work done

GEN-P1 received a battery replacement and a load test.

In the load test GEN-P1 started in 8 seconds and ran for 2 hours at 70 percent load without fault.