

MAXIMA

FORM INSPEKSI MATERIAL INRC & INRA

No. Dokumen	:	FM-02-005-PP	:	Tanggal	:	03 Januari 2018
Revisi	:	01	:	Halaman	:	1

Spesifikasi	: Rectangular wire rope 4x15	Tgl. Inspeksi	: 25 - 3 - 2019
Kode Material	: N/A.0400-C190	Jumlah Datang	: 1
Supplier	: PT. Tontobong.	Jumlah Sampel	: 1
No. PO	: PMA.00137 / PO.0319		

[illegible]

Calculation:

Status Lot:

Robert van der Horst

No. FIM :	
Melaporan :	Mengikuti :
	
Inspector	Spv. Inspector



PT. TONGCHENG MAGNET WIRE

Jl. Jababeka Raya Blok R1 MN. Kawasan Industri Jababeka 1 Cikarang - Bekasi 17530 - Indonesia

Phone : (021) 893-558-9 Fax : (021) 898-332-85 E-mail : tcmw.service@gmail.com

Kepada/ To **PT. MAXIMA DAYA INDONESIA**

Alamat/ Address : Jl. Raya Trawas Km 3.8 RT.57 RW.016
Kel. Sekelagadung Kec. Pongging
Kab. Mojokerto - Jawa Timur

SURAT JALAN

SI No : 513758/TCMW/22032019

DO No : 003758/TCMW/22032019

Tgl/Date : 22 Maret 2019

PO No MDI00137/PO-0319

Kami kirimkan barang-barang sebagai berikut :

We deliver the undermentioned goods:

Samat 25/19

No.	NAMA BARANG Description	TOTAL BOBBIN	GW (Kg)	NW (Kg)	MR/ITEM No.	KETERANGAN Remarks
1	Paper Aluminium Wire 4PCS Ø 15mm	1	55.5	50.5		Pengiriman Ke-1 untuk Total PO 50Kg

KAMI TELAH MENERIMA BARANG-BARANG TERSEBUT DALAM KEADAAN BAIK

(We Confirm received goods in good order and condition)

NOTE 1. Test Report (Terlampir)

2. Picking List (Terlampir)

3. Picking material (Pallet dan Bobbin kembali ke PT. TONGCHENG MAGNET WIRE)

Dengan No Kendaraan:

Vehicle No:

PENERIMA

Received

EKSPEDISI

Expedition

GUDANG

Warehouse

Hormat Kami

Sender

MAXIMA



MAXIMA TRANSFORMER



a subsidiary of
DANA PENSILIN PT PLN (Persero)



PT. MAXIMA DAYA INDONESIA

Jl. Raya Trawas KM 3.8, Pungging - Mojokerto 613
Phone : +62 321 685 000
Fax : +62 321 685 0018
E-mail : info@maximatransformer.com

www.maximatransformer.com

PO Number : MDI 00137/PO-0319
PO Date : 14-March, 2019
Purchaser : Maxima Daya Indonesia
Name : Rochma M
Phone : +62 321 685 0007
Fax : +62 321 685 0018
Email : rochma@maximatransformer.com

Vendor : PT. TONGCHENG MAGNET WIRE
Attn : Ihu Cicih
Address : Jl. Jababeka Raya Blok R1 MN Kawasan Industri
Jababeka I, Cikarang, Bekasi, Jawa Barat
Phone : 021-8935589
Fax : 021-89833285
Email : cicih.g@tongcheng.com.tw
Reference :
Date :

#	Item	Quantity	Price	Discount	VAT	Sub Total
1	RECTANGULAR WIRE PAPER AL 4 x 15	50 kg	IDR 45,000.00	0.00	10%	2,475,000.00
Sub Total:						2,475,000.00
Shipping:						0.00
Total:						2,475,000.00

Delivery Time :
Delivery Point : PT. Maxima Daya Indonesia Jl. Raya
Trawas KM 3.8 Punggi

Payment Terms : 30 Days
Invoice Address : Maxima Daya Indonesia
Tax Registration
Number : 31.583.202.2-602.000

Customer,

Maxima Daya Indonesia,

MAXIMA

Rochma Mud Jayanah Eko Prihartanto

(01 January, 1970)

Document Number: FM-06-003-PP, Revision: 01, Date: 3 January 2018, Pages: 1

maximatransformer.com



PT. TONGCHENG MAGNET WIRE
TCMW/FI/QC/007

Rectangular Alumunium Wire Test Report

PO NO : MDI/00137/PO-0319

PO NO : MDI/00137/PO-0319

Customer	PT.MAXIMA		Test Date	22/03/2019
Size	AL 4.0 x 15.0mm 4PCx 0.05			
Test Item	Unit	Test Standard	Test Result	
Apparance		Surface shall be smoothly and show no crack, scratch or burr	Pass	
Thickness of conductor	mm	3.93 ~ 4.07 mm	3.958	
Widht of conductor	mm	14.85 ~ 15.15 mm	14.935	
Weight of Alumunium wire	g	1M Alumunium Wire / g	156.882g	
Resistance	Ω/KM	Max: 0.4907	0.478	
Conductivity	%	Surpass 61,5 %	62.15%	
Flexibility Test	Deg	Max: 5 °	2.0 °	
Tensile Strength	N/mm2	Under 60 ~ 110 N/mm2	65.81	
Elongation	%	Surpass 20 % above 1	30.00%	
Covered Insulation Paper	mm	1. Overall of Thickness	4.366	
		2. Overall of Width	15.446	
		3. Overlap of Paper	2~3	
Remark Standard : JIS C 3104				OK

(QP-824-01-12-A)

QA departement:



Tester :

Tanggal efektif : 18 Maret 2015