

MAXIMA TRANSFORMER



a subsidiary of
DANA PENSILIN PT PLN (Persero)



PT. MAXIMA DAYA INDONESIA

Jl. Raya Trawas KM 3.8, Pungging - Mojokerto 613
Phone : +62 321 685 000
Fax : +62 321 685 0018
E-mail : info@maximatransformer.com

www.maximatransformer.com

PO Number : MDI-00170/PO-0419
PO Date : 11-April, 2019
Purchaser : Maxima Daya Indonesia
Name : Rochma M
Phone : +62 321 685 0007
Fax : +62 321 685 0018
Email : rochma@maximatransformer.com

Vendor : PT. TONGCHENG MAGNET WIRE
Attn : Iba Cicib
Address : Jl. Jahaheka Raya Blok R1 MN Kawasan Industri
Jahaheka 1, Cikarang, Bekasi, Jawa Barat
Phone : 021-8935589
Fax : 021-89833285
Email : xcib.g@tongcheng.com.cn
Reference :
Date :

#	Item	Quantity	Price	Discount	VAT	Sub Total
1	RECTANGULAR WIRE PAPER AL 2.5 x 14.2 mm	520 kg	IDR 44,800.00	0.00	10%	25,625,600.00
Sub Total:						25,625,600.00
Shipping:						0.00
Total:						25,625,600.00

Delivery Time : 1 Minggu
Delivery Point : PT. Maxima Daya Indonesia Jl. Raya
Trawas KM 3.8 Punggi

Payment Terms : 30 Days
Invoice Address : Maxima Daya Indonesia
Tax Registration
Number : 31.583.202.2-602.000
Maxima Daya Indonesia,

Customer,

MAXIMA

Rochma Mud Jayanth Eko Prihartanto

Document Number: FM-06-003-PP, Revision: 01, Date: 3 January 2018, Pages: 1

maximatransformer.com



PT. TONGCHENG MAGNET WIRE

Jl. Jemberoka Raya Blok PT MM, Kawasan Industri Jemberoka / Cakurung - Bekasi 17530 - Indonesia
Phone : (021) 891-558-9 Fax : (021) 250-152-25 E-mail : tcmw.service@gmail.com

Kepada / To **PT. MAXIMA DATA INDONESIA**

Alamat / Address **Jl. Raya Trawas Km 3.5 RT. 57 RW. 016
Kel. Sekargadung Kas. Pungkir
Kab. Mojokerto - Jawa Timur**

SURAT JALAN KETERANGAN

SI No : 513371/TCMW/2019-0313

DO No : DO3371/TCMW/16042019

Tgl/Date : 16 April 2019

PO No. **MDIC0170/PO-0419**

Kami kirimkan barang-barang sebagai berikut:
We deliver the under mentioned goods

Sonax 22/19
/04

No.	NAMA BARANG Description	TOTAL BOBBIN	GW (Kg)	NW (Kg)	MR/ITEM No.	KETERANGAN Remarks
1	Paper Aluminium Wire 4PC (2.5x14.2mm)	9	598.0	550.0		Pengiriman Ke-1 untuk PO 520kg

KAMI TELAH MENERIMA BARANG-BARANG TERSEBUT DALAM KEADAAN BAIK
We Confirm received goods in good order and condition

NOTE. 1. Test Report (Terlampir)

2. Packing List (Terlampir)

3. Packing material (Pallet dan Bobbin kembali ke PT. TONGCHENG MAGNET WIRE)

Dengan No. Kendaraan
Vehicle No.

PENERIMA

EXPEDISI

GUDANG

Hormat Kami

Sender

MAXIMA

INAM

16/19
/04





PT. TONGCHENG MAGNET WIRE
TMW/F/QC/007

Rectangular Aluminium Wire Test Report

PO NO :MDI00170/PO-0419

Customer	PT.MAXIMA		Test Date	16/04/2019
Size	AL2.5x14.2mm 4PCx 0.05			
Test Item	Unit	Test Standard	Test Result	
Apparance		Surface shall be smoothly and show no crack, scratch or burr	Pass	
Thickness of conductor	mm	2.45 ~ 2.55 mm	2.50	
Widht of conductor	mm	14.05 ~ 14.35 mm	14.187	
Weight of Alumunium wire	g	1M Alumunium Wire / g	93.488g	
Resistance	Ω /km	Max: 0.8218	0.4728	
Conductivity	%	Surpass 62.5 %	62.35%	
Flexibility Test	Deg	Max: 5°	20°	
Tensile Strength	N/mm2	Under 60 ~ 130 N/mm2	78.25	
Elongation	%	Surpass 20 % above	32.88%	
Covered Insulation Paper	mm	1. Overall of Thickness	2.933	
		2. Overall of Width	14.524	
		3. Overlap of Paper	2~3	
Remark Standard : JIS C 3104				OK

(QP-824-01-12-A)

QA departement :



Tester :

Tanggal efektif : 16 Maret 2015