




L2-7 Chapter 3

The Capability Reference Behind Adaptability

Yaowei Huang

1. Why Can Process Not Serve as the Long-Term Reference of a Module?

The previous chapter established that a Laboratory Module is not a predefined room, equipment group, furniture system, experimental workflow, or functional area. Rather, it is an organizational unit formed around Engineering Capability. Its Identity is preserved throughout continuous laboratory change not because its spatial form, equipment configuration, or use pattern remains unchanged, but because the capability structure it organizes can continue to exist through change.

This conclusion naturally leads to another question.

If the Identity of a Module does not depend on a fixed physical state, what should serve as the reference for its adaptability?

In many discussions of laboratory modularity, a Module is often understood as a repeatable spatial unit. It may correspond to a particular process, room type, equipment configuration, or predefined functional combination. Under this interpretation, modularity appears to mean dividing a laboratory into relatively standardized process spaces, then replicating, combining, and arranging them according to project needs.

This interpretation has practical value.

During early planning, spatial standardization, construction organization, and functional communication, using processes or room types as references can improve clarity and help different participants quickly understand the basic composition of a laboratory.

However, when the object of discussion is a laboratory system expected to operate over a long lifecycle, this interpretation reveals a clear explanatory boundary.

The reason is simple.

Processes are not stable.



As discussed in L2-5, laboratory boundaries are not fixed spatial boundaries; they are continuously redefined by risk levels, collaborative relationships, research activities, and operational organization. L2-6 further showed that the ideal workflows and functional order established during design are continually revised by operational reality. In other words, the spatial and process relationships defined in drawings do not remain unchanged throughout the laboratory lifecycle.

If boundaries are reconstructed and workflows are revised, then using a predefined process as the long-term reference of a Module becomes problematic.

A space may be assigned a clear process function during design, yet its experimental content, equipment composition, personnel movement, risk classification, environmental requirements, and interface relationships may all change during later operation. Equipment replacement may alter exhaust requirements. Changes in sample handling may require different pressure relationships. The introduction of automation may introduce new electrical loads, heat removal requirements, and maintenance clearances.

If a Module is referenced directly to a particular process, then the validity of that Module becomes dependent on the stability of that process.

Once the process changes, the Module must also be reinterpreted. A space that was once regarded as a complete Module may no longer carry the same organizational meaning when new engineering demands emerge. Under such conditions, the so-called Module can only describe a process state at a particular stage. It cannot explain why the same organizational unit can remain valid across different process states.

This does not mean that process is unimportant.

On the contrary, process must be carefully understood in laboratory design and operation. However, process is better understood as the specific task a Module supports at a given stage, rather than the long-term reference basis of the Module itself. As suggested by the discussion of furniture and configuration layers in L2-4, many visible elements within a laboratory exist precisely to support adjustment. Yet the configuration layer itself cannot serve as a stable organizational reference.



Therefore, if the purpose of a Module is only to support one fixed process, using process as its reference may be acceptable.

But if a Module is understood as an organizational unit capable of supporting long-term change, it cannot be built directly upon process. Otherwise, every process change would force the Module to be redefined at the level of space, equipment, and function, and modularity would be reduced once again to a method of arranging fixed spatial blocks rather than a true mechanism of long-term adaptability.

The conclusion of this section is therefore clear:

Process can explain what a Module supports at a particular stage, but it cannot serve as the long-term reference for Module adaptability. What allows a Module to remain valid across change is not the process itself, but the Engineering Capability behind that process: capability that can be translated, measured, and governed.

2. How Are Process Requirements Translated into Engineering Capability?

If process cannot serve as the long-term reference of a Module, this does not mean that process can be ignored.

On the contrary, process remains the starting point of laboratory demand.

Every laboratory ultimately exists to support certain activities: sample preparation, testing, analysis, storage, cleaning, observation, containment, calibration, or production. These activities define what the laboratory needs to do at a particular stage. Without understanding them, design would lose its operational basis.

However, process cannot enter the logic of modularity in its original form.

A process name does not directly tell an engineering system how to respond. “PCR,” “sample preparation,” “high-temperature testing,” or “chemical analysis” may describe a laboratory activity, but these names do not by themselves define what the building system must provide, reserve, control, or protect.

For a process to become organizable, it must first be translated into Engineering Capability.

This translation converts process requirements into the engineering conditions that support them. A workflow may imply specific requirements for supply air, exhaust air, pressure control, temperature and humidity stability, heat removal, electrical load, drainage, process gases, waste handling, access control, monitoring, alarms, maintenance clearance, and interface locations. These requirements are not simply technical details added after the process has been defined. They are the form in which the process becomes legible to the engineering system.

In this sense, Engineering Capability is not an abstract concept detached from use. It is the capability expression produced when a process requirement enters the building system and becomes something that can be measured, checked, adjusted, and governed. A laboratory does not organize “process” as a name. It organizes the engineering conditions required for that process to remain possible.

This distinction is important because different engineering disciplines do not share the same logic, unit, or method of judgment.

Airflow cannot be reduced to electrical load. Electrical capacity cannot be treated as the same kind of parameter as drainage, gas supply, pressure control, or environmental monitoring. Each discipline has its own system logic and its own way of defining adequacy, redundancy, tolerance, and risk.

Therefore, the translation from process to Engineering Capability should not be understood as the creation of one universal metric across all disciplines.



What matters is that each discipline can express its capacity in a rational and repeatable way. Its capacity must be identifiable, measurable, checkable, adjustable, and reusable within the organizational logic of the Module. Only when this happens can different technical parameters become part of a shared capability reference, even though they remain different in unit, scale, and professional logic. This is also why a Module cannot be defined simply by a room type or a process label. Two rooms may serve similar processes but require different engineering capacities. Conversely, two different processes may be supported within the same Module if their engineering demands remain within the effective capability range of the same Capability Cluster. What matters is not whether the process names are identical, but whether their underlying engineering demands can be absorbed by the same organized capability structure.

The purpose of translation is therefore to separate the visible activity from the capability condition behind it.

Once process requirements are translated into Engineering Capability, the Module no longer depends on the stability of one specific process. It can begin to judge whether future changes are still within its capability range, whether adjustment is possible, and whether the existing capability structure can continue to support new operational demands.

The conclusion of this section is therefore:

Process is the source of laboratory demand, but Engineering Capability is the form through which that demand becomes organizable. A Module becomes adaptable only when process requirements can be translated into measurable, checkable, adjustable, and governable capability conditions.

3. How Does a Capability Reference Define the Effective Range of a Module?

Once process requirements are translated into Engineering Capability, they still do not automatically form a Module.

At this stage, the requirements may only exist as a collection of technical parameters distributed across different disciplines. These parameters may be measurable, but measurement alone does not yet create modularity.

For a Module to become governable, these capabilities must be organized into a capability reference.

A capability reference is not a single number, nor is it a universal metric that reduces all engineering disciplines into one common scale. It is a structured reference system through which different engineering capacities can be understood, checked, adjusted, and reused within the effective range of a Capability Cluster.

This distinction matters.

Each engineering discipline operates according to its own logic. Each has its own way of defining adequacy, tolerance, reserve, and risk. A capability reference does not erase these differences. Instead, it allows different disciplines to express their capacities in a rational and repeatable way, while making those capacities visible within the same organizational structure.

Only after such a reference exists can a Module begin to define its effective range. The effective range of a Module is the range within which new or changing process demands can still be absorbed by the existing Capability Cluster without requiring upstream reorganization. In other words, a Module remains valid not because every future process has already been predicted, but because future demands can be judged against an organized capacity structure.

This is where the difference between spatial modularity and capability-based modularity becomes clear.

If modularity is based on a predefined room type, then any significant change in process may appear to challenge the Module itself. A room designed for one activity may seem to become invalid once the equipment, workflow, or operational condition changes.

But if modularity is based on capability reference, the question changes.


The question is no longer: "Is this still the same process?"

The question becomes: "Can this new demand still be translated into engineering requirements that remain within the effective capability range of this Module?"

This shift allows the Module to absorb variation without losing its organizational identity.

In engineering practice, such a Capability Cluster is typically manifested as a [Laboratory Cell](#).

• Planning • EHS Logic • Modularity • Commissioning



When a new demand remains within this range, the Module can respond through internal adjustment. Its visible configuration may change, and its operational relationships may be revised, but these changes do not necessarily alter the organizational identity of the Module.

When the demand exceeds this range, however, the situation changes.

If a new requirement can no longer be absorbed by the existing capability structure, or if it requires changes beyond the existing Capability Cluster, then the boundary of the Module begins to appear. At that point, the issue is no longer internal flexibility. It becomes a question of whether the existing Capability Cluster can still maintain its identity.

The conclusion of this section is therefore:

A Module's effective range is defined by its capability reference, not by its room boundary, process name, or initial configuration. As long as changing process demands can be translated into engineering requirements that remain within the effective range of the Capability Cluster, the Module can continue to adjust without being redefined.

4. How Does Capability Reference Support Continuous Adjustment Across the Lifecycle?

If capability reference defines the effective range of a Module, then adaptability is no longer a one-time design feature.

It becomes a lifecycle governance mechanism.

A Module does not become adaptable simply because its space is left open, its furniture is movable, or its layout can be rearranged. These features may support adjustment, but they do not by themselves explain how adjustment is judged, whether it remains within the same Module, or when it begins to exceed the Module's organizational identity.

For adjustment to be meaningful, it must be evaluated against a capability reference.

During design, this reference provides the basis for defining what the Module is expected to absorb. It helps clarify the engineering capacities that must be organized, the interfaces that must remain stable, the reserves that must be protected, and the range of variation the Module is expected to accommodate.

During construction, the same reference becomes a basis for realization and verification.

The question is not only whether the built environment matches the drawing, but whether the built system preserves the capability structure that allows the Module to function and adapt. If the capability reference is weakened during delivery, the Module may appear complete spatially while losing part of its future adaptability.

During operation, the capability reference becomes even more important.

Operational reality continuously produces new demands. Equipment changes. Workflows are revised. User groups expand or contract. Risk relationships shift. Maintenance constraints become visible. Environmental performance is tested under real conditions. These changes do not only affect how a space is used; they test whether the Module's capability structure can continue to absorb variation.

In this process, the Module is not judged by whether it remains visually unchanged.

It is judged by whether new demands can still be translated into engineering requirements that fall within the effective range of the existing Capability Cluster. If they can, the Module may continue through internal adjustment. Its configuration, interfaces, control logic, or operational relationships may be revised, while its organizational identity remains intact.

If they cannot, the issue is no longer ordinary adjustment.

The system must then ask whether the existing capability structure is still sufficient, whether additional capacity must be introduced, whether interfaces must be reorganized, or whether the Module's boundary itself needs to be reconsidered. In this sense, capability reference does not only support adaptation. It also makes the limits of adaptation visible.

This is why the governance of a Module cannot end at handover.

A laboratory system is not stabilized once construction is complete. It continues to evolve through use. The role of modularity is therefore not to freeze the laboratory into a fixed repeatable unit, but to provide a reference structure through which change can be absorbed, evaluated, and governed without constantly returning to upstream reorganization.

The conclusion of this section is therefore:

Capability reference allows a Module to remain continuous across design, construction, and operation. It gives the laboratory system a way to judge change, absorb change, and recognize the point at which change begins to exceed the existing Capability Cluster. Through this mechanism, adaptability becomes not a spatial property, but a form of lifecycle governance.

Conclusion

The discussion above clarifies the capability reference behind Module adaptability. First, process cannot serve as the long-term reference of a Module. A process can explain what a Module supports at a particular stage, but it cannot explain how the same Module remains valid when equipment, workflows, risk relationships, operational arrangements, and environmental requirements continue to change. If a Module is defined primarily by a specific process, its identity becomes dependent on the stability of that process.

Second, process requirements must be translated into Engineering Capability before they can enter the organizational logic of the Module. A laboratory system does not organize a process name. It organizes the engineering conditions required to support that process: airflow, exhaust, pressure control, thermal stability, power demand, drainage, gases, control points, interfaces, and other requirements that can be measured and checked. Through this translation, process change becomes something the engineering system can judge and respond to.

Third, these Engineering Capabilities must form a capability reference within the effective range of a Capability Cluster. This reference does not reduce all disciplines into one universal metric. Instead, it allows different disciplines to express their own capacity ranges in a way that can be measured, checked, adjusted, and governed. The important question is not whether a new demand belongs to the same process category, but whether it can still be absorbed by the existing capability structure.

Finally, capability reference allows a Module to remain adjustable across the lifecycle. Design defines the capability reference. Construction realizes and verifies it. Operation continuously tests, adjusts, and governs it. As long as new demands can still be translated into engineering requirements within the effective range of the Capability Cluster, the Module does not need to be redefined. Its visible configuration may change, but its organizational identity can remain continuous.

The core conclusion of this chapter can therefore be stated as follows:

Module adaptability does not come from the repeated combination of fixed spatial blocks, nor from attachment to a predefined process. It comes from the translation of specific process requirements into Engineering Capability, from the formation of a capability reference within the effective range of a Capability Cluster, and from the continuous checking and governance of that reference throughout design, construction, and operation.



In this sense, modularity should not be understood as a method for arranging fixed process spaces. It should be understood as a mechanism of capability governance. It allows a laboratory system to maintain organizational continuity while its internal conditions continue to change.

Yet no capability reference is unlimited.

A Capability Cluster can absorb change because new demands can still be translated into engineering requirements that remain legible, checkable, and adjustable within the existing capability structure. As long as this relationship holds, the Module can preserve its identity through internal adjustment. But when new demands begin to exceed the existing reference range, the nature of the problem changes.

At that point, the Module is no longer facing only internal adjustment. It is facing the question of whether its capability boundary still holds.

This is where the value and the limit of modularity begin to meet: modularity gains its strength from capability reference, but its limits also emerge from the boundary of that reference.

Yaowei Huang
20260805