Energy_Drink_V15.1 / ENERGY_DRINK_PROC [CPU 314C-2 PN/DP] / Program blocks / 01-MAIN PROCESS

TANK_LEVEL [FC8]

TANK_LEVEL Pr	operties						
General							
Name	TANK_LEVEL	Number	8	Туре	FC	Language	STL
Numbering	Automatic						
Information							
Title		Author		Comment		Family	
Version	0.1	User-defined ID					
7 5.15.15.11		ore. Estimouris		_			

NK_LEVEL me	Data type	Offset	Default value	Comment
r Input	July 19 PC	2.1300	25.44.7.74146	Comment.
	D I			
Tank_Cmd	Bool			
LT_Value	Int			Level transmiter value
Radius	Real			Tank radius
Height	Real			Tank height
Low_Level	Real			
High_Level	Real			
▼ Output				
High_Alarm	Bool			
Low_Alarm	Bool			
Level_Liters	Real			Tank level in liters
Ret_Value	Word			
▼ InOut				
Level_%	DInt			Tank level in %
▼ Temp				
Temp_Level	Real	0.0		
Constant				
▼ Return				
TANK_LEVEL	Void			

```
0001 // LEVEL SENSOR SCALING FROM OUT SIGNAL
0002
     CALL SCALE
0003
           IN
                  :=#LT_Value
0004
            HI LIM :=#Height
0005
            LO LIM :=0.0
0006
             BIPOLAR :=FALSE
0007
             RET_VAL :=#Ret_Value
8000
             OUT
                 :=#Temp_Level
0009
0010 // MAP VAR TEMP_LEVEL TO LEVEL_% TO VISUALIZE THE LEVEL OF THE TANK
0011
         L
               #Temp Level
0012
          L
               10.0
0013
         *R
0014
          RND
0015
                #"Level %"
                                   // LEVEL IN %
0016
```

```
0001 // IF TANK COMMAND => CALCULATE VOLUME IN LITERS BASED ON INPUT PARAMETERS
0002
          U #Tank_Cmd
0003
          SPBN 001
0004
                #Radius
0005
          SQR
0006
          L
               3.1416
          *R
0008
                #Temp_Level
0009
          *R
0010
                1000.0
0011
          *R
0012
                #Level_Liters
                              // LEVEL IN LITERS
0013
0014 _001: NOP 0
0015
0016
```

```
0001 // IF LEVEL >= HIGH_LEVEL => SET HIGH_ALARM
0002 U #Tank_Cmd
0003 U(
0004 L #"Level_%"
0005 DTR
0006 L #High_Level
```

```
Totally Integrated
Automation Portal
0007
       >=R
8000
      )
0009
           #High_Alarm
0001 // IF LEVEL <= LOW_LEVEL => SET HIGH ALARM
0002
       U
           #Tank_Cmd
0003
       U (
0004
       L
          #"Level_%"
0005
      DTR
0006
      L
           #Low_Level
0007
      <=R
8000
0009
           #Low_Alarm
```