



ISO/IEC 17065:2012
10-CPR-009



SGS COLOMBIA S.A.S.

C&P-F490101

ORDEN No. 4200-44838

CERTIFICADO No. CRS28446

ORDEN CERT. No. CO-CERT260200062-01

CERTIFICADO DE CONFORMIDAD DE PRODUCTO

Ningbo Deye Inverter Technology Co., Ltd.

No. 26 South Yongjiang Road, Daqi, Beilun, Ningbo, China

Certifica que el producto identificado como Inversores hasta 50 kW, fabricados en Colombia por Ningbo Deye Inverter Technology Co., Ltd., con referencias relacionadas en las siguientes páginas del presente documento, han sido evaluados de conformidad con:

Resolución 40117 de 02 de abril de 2024 del Ministerio de Minas y Energía de Colombia " Por la cual se modifica el Reglamento Técnico de Instalaciones Eléctricas- RETIE"

Libro 2. Título 2 - Requisitos generales para los productos utilizados en las instalaciones eléctricas. (Artículo. 2.2.1. Artículo. 2.2.2.) Artículo 2.3.23 Inversores

Estos productos han sido sometidos a toma de muestras, inspección, ejecución de pruebas de laboratorio y evaluación del sistema de gestión de calidad del fabricante de acuerdo con el esquema de certificación 5 RETIE.

Resultados obtenidos: CONFORME

Autorizado por:

SGS COLOMBIA S.A.S.

Camilo Ramirez

SGS Colombia S.A.S.

Carrera 100 No. 25C-11, Bodega 3


Bogotá D.C., Colombia

Fecha de Emisión: 2026-02-10

Fecha de Vencimiento: 2031-02-10

Versión 1

Página 1 de 5



Any complaint, appeal or enquiry about the validity of this certificate/report may be sent to sgs.clients@sgs.com, via phone No. (+37) 461006292 and its validity can be checked at <https://www.sgs.com/en/certified-clients-and-products>

This document is issued by the Company under its General Conditions of Service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful, and offenders may be prosecuted to the fullest extent of the law.

C&P-C-06-05 V.7 febrero 2023



SGS COLOMBIA S.A.S.

C&P-F490101

ORDEN No. 4200-44838

CERTIFICADO No. CRS28446

ORDEN CERT. No. CO-CERT260200062-01

CERTIFICADO DE CONFORMIDAD DE PRODUCTO

Ningbo Deye Inverter Technology Co., Ltd.

No. 26 South Yongjiang Road, Daqi, Beilun, Ningbo, China

Inversores hasta 50 kW

Fabricadas por

Ningbo Deye Inverter Technology Co., Ltd.

No. 26 South Yongjiang Road, Daqi, Beilun, Ningbo, China

REFERENCE	TYPE OF PRODUCT	NOMINAL INPUT VOLTAGE (V)	AC RATED VOLTAGE (V)	AC MAX CURRENT (A)	RATED FREQUENCY (Hz)	AC MAX. CHARGING/DISCHARGING CURRENT (A)	AC NOMINAL PKW (kW)	AC MAX. APPARENT POWER (kVA)	GRID SYSTEM PATTERN
SUN-6K-G06-LV	On Grid Inverter	800	3L/N/PE 127/220V 133/230V	15.8/15.1	50/60	15.8/15.1	6	6	3L/N/PE
SUN-8K-G06-LV	On Grid Inverter	800	3L/N/PE 127/220V 133/230V	21/20.1	50/60	21/20.1	8	8	3L/N/PE
SUN-10K-G05-LV	On Grid Inverter	800	3L/N/PE 127/220V 133/230V	26.3/25.1	50/60	26.3/25.1	10	10	3L/N/PE
SUN-15K-G05-LV	On Grid Inverter	800	3L/N/PE 127/220V 133/230V	39.4/37.6	50/60	39.4/37.6	15	12	3L/N/PE
SUN-12K-G05-LV	On Grid Inverter	800	3L/N/PE 127/220V 133/230V	31.5/30.1	50/60	31.5/30.1	12	15	3L/N/PE
SUN-5K-SG05LP2-US-SM2	Hybrid Inverter	500	2L+N+PE 120/240; 208	20.9	50/60	20.9	5	5	2L+N+PE
SUN-6K-SG05LP2-US-SM2	Hybrid Inverter	500	2L+N+PE 120/240; 208	25	50/60	25	6	6	2L+N+PE
SUN-8K-SG05LP2-US-SM2	Hybrid Inverter	500	2L+N+PE 120/240; 208	33.4	50/60	33.4	8	8	2L+N+PE
SUN-10K-SG05LP2-US-SM2	Hybrid Inverter	500	2L+N+PE 120/240; 208	41.7	50/60	41.7	10	10	2L+N+PE
SUN-12K-SG05LP2-US-SM2	Hybrid Inverter	500	2L+N+PE 120/240; 208	50	50/60	50	12	12	2L+N+PE
SUN-5K-SG01LP1-US	Hybrid Inverter	500	2L+N+PE 120/240; 208	22.9	50/60	22.9	5	5.5	2L+N+PE
SUN-6K-SG01LP1-US	Hybrid Inverter	500	2L+N+PE 120/240; 208	27.5	50/60	27.5	6	6.6	2L+N+PE
SUN-7.6K-SG01LP1-US	Hybrid Inverter	500	2L+N+PE 120/240; 208	34.8	50/60	34.8	7.6	8.36	2L+N+PE
SUN-8K-SG01LP1-US	Hybrid Inverter	500	2L+N+PE 120/240; 208	36.7	50/60	36.7	8	8.8	2L+N+PE
SUN-1.5K-G04P1-EU-AM1	On Grid Inverter	550	2L+N+PE 120/240; 208	7.5/7.2	50/60	7.5/7.2	1.5	1.65	2L+N+PE
SUN-2K-G04P1-EU-AM1	On Grid Inverter	550	L/N/PE 220/230V	10/9.6	50/60	10/9.6	2	2.2	L/N/PE
SUN-2.5K-G04P1-EU-AM1	On Grid Inverter	550	L/N/PE 220/230V	12.5/12	50/60	12.5/12	2.5	2.75	L/N/PE
SUN-3K-G04P1-EU-AM1	On Grid Inverter	550	L/N/PE 220/230V	15/14.4	50/60	15/14.4	3	3.3	L/N/PE
SUN-3.6K-G04P1-EU-AM1	On Grid Inverter	550	L/N/PE 220/230V	18/17.3	50/60	18/17.3	3.6	3.96	L/N/PE
SUN-4K-G04P1-EU-AM1	On Grid Inverter	550	L/N/PE 220/230V	20/19.2	50/60	20/19.2	4	4.4	L/N/PE
SUN-3.6K-G05P1-EU-AM2	On Grid Inverter	550	L/N/PE 220/230V	18.0/17.3	50/60	18.0/17.3	3.6	3.96	L/N/PE
SUN-4K-G05P1-EU-AM2	On Grid Inverter	550	L/N/PE 220/230V	20.0/19.2	50/60	20.0/19.2	4	4.4	L/N/PE

Fecha de Emisión: 2026-02-10

Fecha de Vencimiento: 2031-02-10

Versión 1

Página 2 de 5



Any complaint, appeal or enquiry about the validity of this certificate/report may be sent to sgs.colombia@sgs.com, via phone No. (+57) 461069292 and its validity can be checked at <https://www.sgs.com/en/certified-clients-and-products>

This document is issued by the Company under its General Conditions of Service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful, and offenders may be prosecuted to the fullest extent of the law.

C&P-C-06-05 V.7 febrero 2023



SGS COLOMBIA S.A.S.
C&P-F490101
ORDEN No. 4200-44838
CERTIFICADO No. CRS28446
ORDEN CERT. No. CO-CERT260200062-01
CERTIFICADO DE CONFORMIDAD DE PRODUCTO
Ningbo Deye Inverter Technology Co., Ltd.
No. 26 South Yongjiang Road, Daqi, Beilun, Ningbo, China

REFERENCE	TYPE OF PRODUCT	NOMINAL INPUT VOLTAGE (V)	AC RATED VOLTAGE (V)	AC MAX CURRENT (A)	RATED FREQUENCY (Hz)	AC MAX. CHARGING/DISCHARGING CURRENT (A)	AC NOMINAL PKW (kW)	AC MAX. APPARENT POWER (kVA)	GRID SYSTEM PATTERN
SUN-5K-G05P1-EU-AM2	On Grid Inverter	550	L/N/PE 220/230V	25.0/24.0	50/60	25.0/24.0	5	5.5	L/N/PE
SUN-6K-G05P1-EU-AM2	On Grid Inverter	550	L/N/PE 220/230V	30.0/28.7	50/60	30.0/28.7	6	6.6	L/N/PE
SUN-3.6K-G05P1-EU-CM2	On Grid Inverter	550	L/N/PE 220/230V	18.0/17.3	50/60	18.0/17.3	3.6	3.96	L/N/PE
SUN-4K-G05P1-EU-CM2	On Grid Inverter	550	L/N/PE 220/230V	20.0/19.2	50/60	20.0/19.2	4	4.4	L/N/PE
SUN-5K-G05P1-EU-CM2	On Grid Inverter	550	L/N/PE 220/230V	25.0/24.0	50/60	25.0/24.0	5	5.5	L/N/PE
SUN-6K-G05P1-EU-CM2	On Grid Inverter	550	L/N/PE 220/230V	30.0/28.7	50/60	30.0/28.7	6	6.6	L/N/PE
SUN-18K-G05	On Grid Inverter	1100	3L/N/PE 220/380V 230/400V	30/28.7	50/60	30/28.7	18	19.8	3L/N/PE
SUN-20K-G05	On Grid Inverter	1100	3L/N/PE 220/380V 230/400V	33.3/31.9	50/60	33.3/31.9	20	22	3L/N/PE
SUN-25K-G05	On Grid Inverter	1100	3L/N/PE 220/380V 230/400V	41.7/39.8	50/60	41.7/39.8	25	27.5	3L/N/PE
SUN-40K-G04	On Grid Inverter	1100	3L/N/PE 220/380V 230/400V	66.7/63.8	50/60	66.7/63.8	40	44	3L/N/PE
SUN-45K-G04	On Grid Inverter	1100	3L/N/PE 220/380V 230/400V	75.0/71.7	50/60	75.0/71.7	45	49.5	3L/N/PE
SUN-50K-G04	On Grid Inverter	1100	3L/N/PE 220/380V 230/400V	83.3/79.7	50/60	83.3/79.7	5	55	3L/N/PE
SUN-8K-SG01HP3-US-AM2	Hybrid Inverter	550	3L/N/PE 120/208V	22.3	50/60	22.3	8	8	3L/N/PE
SUN-10K-SG01HP3-US-AM2	Hybrid Inverter	550	3L/N/PE 120/208V	27.8	50/60	27.8	10	10	3L/N/PE
SUN-12K-SG01HP3-US-AM2	Hybrid Inverter	550	3L/N/PE 120/208V	33.4	50/60	33.4	12	12	3L/N/PE
SUN-15K-SG01HP3-US-AM2	Hybrid Inverter	550	3L/N/PE 120/208V	41.7	50/60	41.7	15	15	3L/N/PE
SUN-M130G4-EU-Q0	Micro Inverter	60	L/N/PE 220/230V	6.0/5.7	50/60	6.0/5.7	1.3	1.3	L/N/PE
SUN-M160G4-EU-Q0	Micro Inverter	60	L/N/PE 220/230V	7.3/7	50/60	7.3/7	1.6	1.6	L/N/PE
SUN-M180G4-EU-Q0	Micro Inverter	60	L/N/PE 220/230V	8.2/7.9	50/60	8.2/7.9	1.8	1.8	L/N/PE
SUN-M200G4-EU-Q0	Micro Inverter	60	L/N/PE 220/230V	9.1/8.7	50/60	9.1/8.7	2	2	L/N/PE
SUN-M220G4-EU-Q0	Micro Inverter	60	L/N/PE 220/230V	10/9.6	50/60	10/9.6	2.2	2.2	L/N/PE
SUN-M130G4-EU-Q0-I	Micro Inverter	60	L/N/PE 220/230V	6.0/5.7	50/60	6.0/5.7	1.3	1.3	L/N/PE
SUN-M160G4-EU-Q0-I	Micro Inverter	60	L/N/PE 220/230V	7.3/7	50/60	7.3/7	1.6	1.6	L/N/PE
SUN-M180G4-EU-Q0-I	Micro Inverter	60	L/N/PE 220/230V	8.2/7.9	50/60	8.2/7.9	1.8	1.8	L/N/PE
SUN-M200G4-EU-Q0-I	Micro Inverter	60	L/N/PE 220/230V	9.1/8.7	50/60	9.1/8.7	2	2	L/N/PE
SUN-M220G4-EU-Q0-I	Micro Inverter	60	L/N/PE 220/230V	10/9.6	50/60	10/9.6	2.2	2.2	L/N/PE

Fecha de Emisión: 2026-02-10
 Fecha de Vencimiento: 2031-02-10
 Versión 1

Página 3 de 5



Any complaint, appeal or enquiry about the validity of this certificate/report may be sent to sgs.colombia@sgs.com, via phone No. (+57) 461006292 and its validity can be checked at <https://www.sgs.com/en/certified-clients-and-products>.

This document is issued by the Company under its General Conditions of Service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful, and offenders may be prosecuted to the fullest extent of the law.

C&P-C-06-05 V.7 febrero 2023



SGS COLOMBIA S.A.S.
C&P-F490101
ORDEN No. 4200-44838
CERTIFICADO No. CRS28446
ORDEN CERT. No. CO-CERT260200062-01
CERTIFICADO DE CONFORMIDAD DE PRODUCTO
Ningbo Deye Inverter Technology Co., Ltd.
No. 26 South Yongjiang Road, Daqi, Beilun, Ningbo, China

REFERENCE	TYPE OF PRODUCT	NOMINAL INPUT VOLTAGE (V)	AC RATED VOLTAGE (V)	AC MAX CURRENT (A)	RATED FREQUENCY (Hz)	AC MAX. CHARGING/DISCHARGING CURRENT (A)	AC NOMINAL PKW (kW)	AC MAX. APPARENT POWER (kVA)	GRID SYSTEM PATTERN
SUN-M60G5-US-M2-Q1	Micro Inverter	60	L/N/PE 208/240V	3.2/2.8	50/60	3.2/2.8	0,6	0,66	L/N/PE
SUN-M80G5-US-M2-Q1	Micro Inverter	60	L/N/PE 208/240V	4.3/3.7	50/60	4.3/3.7	0,8	0,88	L/N/PE
SUN-M100G5-US-M2-Q1	Micro Inverter	60	L/N/PE 208/240V	5.3/4.6	50/60	5.3/4.6	1	1,1	L/N/PE
SUN-M110G5-US-M2-Q1	Micro Inverter	60	L/N/PE 208/240V	5.3/4.6	50/60	5.3/4.6	1,1	1,1	L/N/PE
SUN-M65G5-US-Q1	Micro Inverter	60	L/N/PE 208/240V	3.9/3.4	50/60	3.9/3.4	0,65	0,8	L/N/PE
SUN-M80G5-US-Q1	Micro Inverter	60	L/N/PE 208/240V	4.3/3.7	50/60	4.3/3.7	0,8	8,8	L/N/PE
SUN-M100G5-US-Q1	Micro Inverter	60	L/N/PE 208/240V	5.3/4.6	50/60	5.3/4.6	1	1,1	L/N/PE
SUN-S130G4-EU-Q0	Micro Inverter	60	L/N/PE 220/230V	6.0/5.7	50/60	6.0/5.7	1,3	1,3	L/N/PE
SUN-S160G4-EU-Q0	Micro Inverter	60	L/N/PE 220/230V	7.3/7	50/60	7.3/7	1,6	1,6	L/N/PE
SUN-S180G4-EU-Q0	Micro Inverter	60	L/N/PE 220/230V	8.2/7.9	50/60	8.2/7.9	1,8	1,8	L/N/PE
SUN-S200G4-EU-Q0	Micro Inverter	60	L/N/PE 220/230V	9.1/8.7	50/60	9.1/8.7	2	2	L/N/PE
SUN-S220G4-EU-Q0	Micro Inverter	60	L/N/PE 220/230V	10/9.6	50/60	10/9.6	2,2	2,2	L/N/PE
SUN-M130G5-EU-Q1	Micro Inverter	60	L/N/PE 220/230V	6.0/5.7	50/60	6.0/5.7	1,3	1,3	L/N/PE
SUN-M160G5-EU-Q1	Micro Inverter	60	L/N/PE 220/230V	7.3/7	50/60	7.3/7	1,6	1,6	L/N/PE
SUN-M180G5-EU-Q1	Micro Inverter	60	L/N/PE 220/230V	8.2/7.9	50/60	8.2/7.9	1,8	1,8	L/N/PE
SUN-M200G5-EU-Q1	Micro Inverter	60	L/N/PE 220/230V	9.1/8.7	50/60	9.1/8.7	2	2	L/N/PE
SUN-M220G5-EU-Q1	Micro Inverter	60	L/N/PE 220/230V	10/9.6	50/60	10/9.6	2,2	2,2	L/N/PE

NÚMERO DE REPORTE Y LABORATORIO:

1. GZES250400593401. SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch.
2. 251000166SHA-001. TÜV Rheinland (Shanghai) Co., Ltd.
3. CN25LZNV 001. Intertek Testing Services (Shanghai FTZ) Co., Ltd.

USOS:

1. El inversor debe ser instalado y mantenido por personal calificado según las regulaciones estándar locales.
2. Primero debe desconectar el lado de CA y luego desconectar el lado de CC mientras realiza la instalación y el mantenimiento. Después de eso, espere al menos 5 minutos para evitar recibir descargas eléctricas.
3. La temperatura local del inversor puede superar los 80 °C durante su funcionamiento. No lo toque para evitar lesiones.
4. Toda instalación eléctrica debe realizarse de acuerdo con las normas eléctricas locales y, después de obtener el permiso del departamento de suministro de energía local, los profesionales pueden conectar el inversor a la red.
5. Tome las medidas antiestáticas adecuadas.
6. Instálelo en un lugar donde los niños no puedan tocarlo.

Fecha de Emisión: 2026-02-10

Fecha de Vencimiento: 2031-02-10

Versión 1

Página 4 de 5



Any complaint, appeal or enquiry about the validity of this certificate/report may be sent to sgs.compliance@sgs.com, via phone No. (+37) 461006292 and its validity can be checked at <https://www.sgs.com/en/certified-clients-and-products>.

This document is issued by the Company under its General Conditions of Service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful, and offenders may be prosecuted to the fullest extent of the law.

C&P-C-06-05 V.7 febrero 2023





ISO/IEC 17065:2012
10-CPR-009



SGS COLOMBIA S.A.S.

C&P-F490101

ORDEN No. 4200-44838

CERTIFICADO No. CRS28446

ORDEN CERT. No. CO-CERT260200062-01

CERTIFICADO DE CONFORMIDAD DE PRODUCTO

Ningbo Deye Inverter Technology Co., Ltd.

No. 26 South Yongjiang Road, Daqi, Beilun, Ningbo, China

7. Los pasos para iniciar el inversor: 1) encienda el disyuntor del lado de CA, 2) encienda el disyuntor del lado de CC del panel fotovoltaico. 3) Encienda el interruptor de CC del inversor. Los pasos para detener el inversor: 1) apague el disyuntor del lado de CA, 2) apague el disyuntor del lado de CC del panel fotovoltaico. 3) Apague el interruptor de CC del inversor.
8. No inserte ni retire terminales de CA y CC cuando el inversor esté en funcionamiento normal.
9. La tensión de entrada de CC del inversor no debe superar el valor máximo del modelo.

PROHIBICIONES:

Se prohíbe el uso de un solo disyuntor para varios inversores, así como la conexión de cargas entre los disyuntores de los inversores.


*****FIN DEL DOCUMENTO*****

Fecha de Emisión: 2026-02-10

Fecha de Vencimiento: 2031-02-10

Versión 1

Página 5 de 5



Any complaint, appeal or enquiry about the validity of this certificate/report may be sent to sgs.enquiries@sgs.com, via phone No. (+37) 461069292 and its validity can be checked at <http://www.sgs.com/en/certified-clients-and-products>.

This document is issued by the Company under its General Conditions of Service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful, and offenders may be prosecuted to the fullest extent of the law.

C&P-C-06-05 V.7 febrero 2023

