



Relationships built on trust



Gamcorp Pty Ltd ACN: 665 643 658 ABN: 86 665 643 658
www.gamcorp.com.au rocla@gamcorp.com.au
Tel: 03 9543 2211

Job No: 16721

Date: 02/09/2025

Ref: LvS

Project: Austins Ferry TAS

Client: CIVILMART - ROCLA POLES

Australian Standards

- AS 1170 – Structural Design Actions
 - Part 0 – General Principles
 - Part 1 – Permanent Imposed and Other Actions
 - Part 2 – Wind Actions
 - Part 3 – Snow and Ice Actions
- AS 2159 – Piling – Design and Installation
- AS 3600 – Concrete Structures
- AS 4100 – Steel Structures
- AS 4678 – Earth-Retaining Structures

References: 01640 dated 6/3/2015 by Strata Geoscience and environmental PTY LTD.

	<u>Allowable Bearing Pressure</u>	<u>Concrete Strengths</u>
<u>Pads :</u>	330 kPa	32 MPa



gamcorp

Relationships built on trust

CIVILMART
Rocla Poles



FOUNDATION CERTIFICATE

Client: Rocla Concrete Poles
Project: Pole Foundation Design
Site Name: Austins Ferry TAS
Site No: H8097

Date: 02/09/2025
Ref: LvS

POLE DETAILS

Type: SR3-BM27-585
Height (AGL): 27 m
SRF= 1

FOOTING DETAILS

Footing Type: 5.5m x 5.5m x 2.3m Deep Pad Footing
Footing Rotation°: 0.07° (ULS; M @ GL = 2400 kNm)
0.02° (SLS; M @ GL = 720 kNm)

Drawing No: Telstra drawings T110568, sheets T2

ASSESSMENT

Based on the geotechnical information provided, the 5.5m x 5.5m x 2.3m Deep Pad Footing deemed suitable for this SR3-BM27-585 pole and partially a shelter (2 corners of it).

CERTIFIED BY

L. Van Spaandonk

FIEAust CPEng NER 5038980

NT Registration: 244137ES

QLD Registration: 18703

VIC Registration: PE0001956

TAS Registration: CC7366