ANALYSIS TEMPLATE REPORT

Primary Element		nt	Secondary Element	Weight	Unit	Element Rate		Value	
84 . F	Electrica	ıl Work							
84-110)-20 Di	istribution	wiring (surface conduit) : fan point(Eastern)						
40.	Metal V	<u>Vork</u>							
		40-580	Screw, 19mm	1.0000	dzn	@ Tkper	dzn	Tk	
						Sub Total —		Tk	
60.	Electric	al Work							
		60-107	Box, Joint	0.2500	No.	@ Tkper	No.	Tk	
		60-160	Ceiling Rose	1.0000	No.	@ Tkper	No.	Tk	
		60-417	Pipe, Conduit, P.V.C., 25 mm dia	7.0000	m	@ Tkper 10	00 m	Tk	
		60-470	Round Block	1.0000	No.	@ Tkper	No.	Tk	
		60-480	Rowel Plug	1.0000	dzn	@ Tkper	dzn	Tk	
		60-488	Saddles	6.0000	No.	@ Tkper	No.	Tk	
		60-740	Switch, Tumbler, 5 A	1.0000	No.	@ Tkper	No.	Tk	
		60-832	Wire, Copper, SWG, No. 16	0.0700	kg	@ Tkper	kg	Tk	
		60-860	Wire,PVC; 1C;1.5mm ² ; 250/400V	14.0000	m	@ Tkper 10	00 m	Tk	
						Sub Total —		Tk	
80.	Labour								
		80-190	Electrician	0.2500	day	@ Tkper	day	Tk	
		80-200	Electrician, Helper	0.2500	day	@ Tkper	day	Tk	
		80-200	(Electrician, Helper)	0.0014	day	@ Tkper	day	Tk (Misc. Sund	
			, , ,	0.0011	Ž	Sub Total —		Tk	
						Sum of Sub Tota	1	Tk	
						Overhead &	2.5	Tk	
						Item Total		Tk	
						Contractor's	10 %	Tk	
						Total		Tk	
						VAT	5.5 %	Tk	
						Item Grand Tota	l	Tk	