## ANALYSIS TEMPLATE REPORT

Primary Element		Secondary Element	Weight	Unit	Element Rate		Value	
84 . Elec	ctrical Work							
84-190-25	Concealed co	onduit wiring: 1C, 2-1x4.0mm²; Eastern						
10. <u>N</u>	Materials : Concre	<u>ete</u>						
	10-100	Cement: Portland	0.3300	kg	@ Tkper	kg	Tk	
	10-380	Sand, FM >= 1.5	0.0014	cum	@ Tkper	cum	Tk	
					Sub Total —		Tk	
40. <u>N</u>	Metal Work							
	40-585	Screw, 25mm	0.5000	dzn	@ Tkper	dzn	Tk	
					Sub Total -		Tk	
60. <u>F</u>	Electrical Work							
	60-417	Pipe, Conduit, P.V.C., 25 mm dia	1.0000	m	@ Tkper 1	.00 m	Tk	
	60-480	Rowel Plug	0.5000	dzn	@ Tkper	dzn	Tk	
	60-488	Saddles	3.0000	No.	@ Tkper	No.	Tk	
	60-831	Wire, Copper, SWG, No. 14	0.0185	kg	@ Tkper	kg	Tk	
	60-862	Wire,PVC; 1C; 4.0mm <sup>2</sup> ;	2.0000	m	@ Tkper 1	00 m	Tk	
					Sub Total -		Tk	
80. <u>L</u>	_abour							
	80-190	Electrician	0.0200	day	@ Tkper	day	Tk	
	80-200	Electrician, Helper	0.0150	day	@ Tkper	day	Tk	
	80-200	(Electrician, Helper)	0.0002	day	@ Tkper	day	Tk (Misc. Sundi	
	80-425	Mason	0.0400	day	@ Tkper	day	Tk	
	80-430	Mason, Head	0.0080	day	@ Tkper	day	Tk	
	80-435	Mason, Helper	0.0700	day	@ Tkper	day	Tk	
					Sub Total -		Tk	
					Sum of Sub Tot	al	Tk	
					Overhead &	2.5	Tk	
					Item Total		Tk	
					Contractor's	10 %	Tk	
					Total		Tk	
					VAT		Tk	
					Item Grand Tot	tal	Tk	