ANALYSIS TEMPLATE REPORT

Primary Element			Secondary Element	Weight	Unit	Element Rate		Value
84 . I	Electrical	Work						
84-160	0-40 Surf	face cond	luit wiring: 3C, 1-3x6.0mm²; BRB/Jam/Sun					
40.	Metal Wo	<u>ork</u>						
	4	40-585	Screw, 25mm	0.5000	dzn	@ Tkper	dzn	Tk
						Sub Total —		Tk
60.	Electrical	Work						
	(60-417	Pipe, Conduit, P.V.C., 25 mm dia	1.0000	m	@ Tkper 100) m	Tk
	(60-480	Rowel Plug	0.5000	dzn	@ Tkper	dzn	Tk
	(60-488	Saddles	0.2500	No.	@ Tkper	No.	Tk
	(60-831	Wire, Copper, SWG, No. 14	0.0290	kg	@ Tkper	kg	Tk
	(60-958	Wire, PVC;	1.0000	m	@ Tkper 100) m	Tk
						Sub Total —		Tk
80.	Labour							
	;	80-190	Electrician	0.0335	day	@ Tkper	day	Tk
	;	80-200	Electrician, Helper	0.0335	day	@ Tkper	day	Tk
	:	80-200	(Electrician, Helper)	0.0030	day	@ Tkper	day	Tk (Misc. Sundr
						Sub Total —		Tk
						Sum of Sub Total		Tk
						Overhead &	2.5	Tk
						Item Total		Tk
						Contractor's	10 %	Tk
						Total		Tk
						VAT		Tk
						Item Grand Total		Tk