

Pathways and Spaces

Conduit Fill

Conduit fill for low-voltage communications cabling shall not exceed 40 percent when three or more cables are present. For a single cable, 53 percent fill is permitted. These percentages account for future access and thermal management.

- Multiple cables: 40 % fill maximum
- Single cable: 53 % fill maximum

Cable Tray Loading

Ladder-type cable trays shall support a uniform load of 22.7 kg per metre without structural deformation. The working-load deflection limit is span divided by 200. Support spacing shall not exceed 2.4 metres for standard installations.

Access Flooring

Raised-floor plenum spaces are classified as air-handling spaces. Cables installed under raised flooring in data centres must be plenum-rated when the cavity is used for air return.