

Grounding and Bonding for Telecommunications

Telecommunications Bonding

The telecommunications bonding backbone (TBB) shall be a 6 AWG copper conductor minimum. It connects the telecommunications main grounding busbar (TMGB) to each telecommunications grounding busbar (TGB) in intermediate and floor-serving rooms.

- TBB size: 6 AWG minimum
- TBB connects TMGB to every TGB

Ground Resistance

The resistance from any TGB to the main electrical service ground shall not exceed 1 ohm. This is verified with a fall-of-potential earth-resistance test after installation.

Equipment Bonding

Each rack and cabinet shall be bonded to the room TGB with a 6 AWG conductor. Separate conductors shall not be daisy-chained; each rack receives a dedicated bonding jumper.