

Fire Stopping and Smoke Sealing

Penetration Ratings

Penetrations through fire-rated walls and floors must maintain the fire-resistance rating of the assembly. Intumescent sealants rated for F and T ratings are required. A 2-hour rated wall requires a matching 2-hour fire-stop system.

- F rating: flame barrier integrity
- T rating: temperature rise limit
- Both ratings required for penetrations

Cable Penetration Sleeves

Metallic sleeves cast or core-drilled into concrete floors must extend 25 mm above and below the slab surface. Sleeves shall be filled with approved intumescent caulk after cable installation.