

Cable Management and Labelling

Labeling Standard

TIA-606-B requires unique identifiers for every cable, outlet, and patch panel port. Labels shall be machine-printed; handwritten labels are non-compliant. The identifier format is: BLD-FLR-TR-PORT (building-floor-telecom room-port).

- Machine-printed only
- Format: BLD-FLR-TR-PORT

Colour Coding

Patch cords should follow a colour scheme for service segmentation: blue for data, yellow for voice, white for POE devices, and red for critical or security circuits.

Cable Slack

A service loop of 3 metres minimum shall be left at each telecommunications room end. Horizontal cabling shall have 300 mm of slack at the work area outlet.

- TR service loop: 3 m
- Work area slack: 300 mm