

Testing and Certification

Insertion Loss Limits

Certification testers measure insertion loss against channel and permanent-link limits. For Cat 6A at 250 MHz, the insertion loss limit is 20.9 dB for the channel and 16.8 dB for the permanent link. NEXT must exceed 32.9 dB at 250 MHz.

- Cat 6A insertion loss: 20.9 dB (channel), 16.8 dB (permanent link) at 250 MHz
- Cat 6A NEXT: >32.9 dB at 250 MHz

Test Reports

A permanent record of every test result shall be retained for the warranty period. Reports must include tester serial number, cable ID, date, and pass/fail status for all parameters.

Autotest Duration

A full Cat 6A autotest using a Level V tester requires approximately 12 seconds per link. Batch testing of 100 links can be completed in under 30 minutes including setup time.