

Plenum and Riser Cable Ratings

Plenum Rating (CMP)

Plenum-rated cables (CMP) meet NFPA 262 flame and smoke requirements. They are required in any air-handling space, including raised-floor plenums and drop-ceiling returns. Plenum-rated cables must be marked with the CMP legend in continuous print. Temperature rating for plenum cable is 75 degrees Celsius under continuous load.

- Standard: NFPA 262
- Required in: air-handling spaces
- Temperature rating: 75 C continuous

Riser Rating (CMR)

Riser-rated cables (CMR) comply with UL 1666. They are permitted in vertical shafts between floors but not in air-handling plenums. CMR cable must exhibit limited flame spread when tested in the vertical tray flame test.

- Standard: UL 1666
- Permitted: vertical risers
- Prohibited: air-handling plenums