

Outside Plant and Campus Cabling

Underground Ducts

Campus cabling between buildings is placed in underground duct banks. A minimum of four 90 mm inner-ducts is recommended for a two-building link, providing one inner-duct for current fibre, one for copper, and two for future expansion.

- Minimum inner-ducts: 4 per link
- Duct size: 90 mm typical

Direct Burial

Direct-burial cable requires a minimum cover depth of 600 mm in pedestrian areas and 1,200 mm in traffic-bearing zones. Warning tape marked with the word CABLE shall be placed 300 mm above every direct-burial cable.

- Pedestrian cover: 600 mm
- Traffic cover: 1,200 mm
- Warning tape: 300 mm above cable

Aerial Span

Aerial campus fibre shall be lashed to a messenger wire with a maximum span of 70 metres between support poles. Aerial cable must be all-dielectric self-supporting (ADSS) when electrical hazards exist on the pole route.