

Telecommunications Room Standards

Room Size

A telecommunications room serving a single floor shall be a minimum of 3 metres by 3.6 metres. Each additional 1,000 square metres of served area requires an additional 0.5 square metres of rack space in the room. Ceiling height shall be 2.7 metres minimum.

- Minimum room: 3 m x 3.6 m
- Ceiling height: 2.7 m minimum

Environmental Requirements

Telecommunications rooms shall be maintained between 18 and 24 degrees Celsius and between 30 and 55 percent relative humidity. Temperature change rate shall not exceed 5 degrees per hour.

- Temperature: 18 C to 24 C
- Humidity: 30 % to 55 % RH
- Change rate: ≤ 5 C per hour

Equipment Layout

Cable termination hardware shall be wall-mounted or rack-mounted. Wall-mounted panels require a plywood backboard of 19 mm thickness, painted with fire-retardant paint. Racks shall be spaced at minimum 900 mm apart for rear access.

- Backboard: 19 mm plywood, fire-retardant paint
- Rack spacing: 900 mm minimum