

Automated PSC Test Report

Procedure Performed on 8/18/2025 by Thomas Chiesa and Anthony Caracappa

Analysis Performed on 8/25/2025 by Thomas Chiesa

DAC Readback Measurements

Channel 1 1.0 Amp Command	Readback Value:	0.995178
	Within tolerance?	PASS
Channel 2 1.0 Amp Command	Readback Value:	0.993347
	Within tolerance?	PASS
Channel 3 1.0 Amp Command	Readback Value:	0.998840
	Within tolerance?	PASS
Channel 4 1.0 Amp Command	Readback Value:	0.994263
	Within tolerance?	PASS

EVR Monotonic TimeStamp Test		
EVR Link Test	Readback Values:	1756833602, 1756833603, 1756833605
	EVR Working?	PASS