

TEST REPORT

2603 - 12th Street, SE
Salem, OR 97302
Voice: (503) 363-0473
FAX: (503) 363-8900

TO: Aqua Pro Pump Service
36967 Plagmann Dr NE
Albany, OR 97322

4/28/2021

AQUPRO

PO#:

Collection Information

Date: 4/21/2021
Time: 1345
By: KB
Lab #: 20210421-043
Location: 308 NE South Nebergal Loop well os tap

Lab Receipt Information

4/21/2021
1538
SW

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

| Analyte | Method | Acc* | Results | Qual | MRL | Units | EPA Limit | Analysis | |
|-------------------|----------|------|---------|------|-------|--------|-----------|-----------|---------|
| | | | | | | | | Date Time | Tech |
| Arsenic, Nitrate | | | | | | | | | |
| Arsenic | SM3113B | A | ND | | 0.002 | mg/l | 0.010 | 4/27/2021 | BEM |
| Nitrogen, Nitrate | EPA300.0 | A | 3.10 | | 0.2 | mg/l N | 10. | 4/21/2021 | 1945 AS |

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: _____

