

8.1 Does Part 75 require periodic quality QA/QC testing after a monitoring system is certified?

Following initial certification, all Part 75 monitoring systems are required to undergo periodic quality-assurance testing, to ensure that they continue to provide accurate data.

- For CEMS, the QA test requirements are found in either:
 - ☐ Appendix B of Part 75 and §75.21, for sources that report emissions data year-round; or
 - ☐ Section 75.74(c), for CAIR NO_x units that report emissions data only for the ozone season months (from May 1st through September 30th)
- For Appendix D fuel flowmeter systems, the on-going QA test requirements are in section 2.1.6 of Appendix D; and
- For Appendix E NO_x correlation curve systems, the QA requirements are found in sections 2.2 and 2.3 of Appendix E.