

6.5.3 Appendix E Test Results

For a peaking unit switching from the Appendix E methodology (see Section 5 of this guide) to LME, the results of a previous four-load Appendix E NO_x emission test may be used to determine the site-specific default NO_x emission rates, provided that the test results are less than 5 years old.