

3.4.3 *Determining heat input rate, in mmBtu/hr*

To determine the hourly heat input rate (mmBtu/hr), the stack gas flow rate (scfh) is divided by the appropriate F-factor (scf/mmBtu), and a correction for excess air is applied, using the measured diluent gas concentration. A moisture correction may also be required.