

## Applications Sub-Tab

The *Applications Sub-Tab* contains alarm logs from each of the *SpectraView® Prism Services*, as seen in **FIGURE ERROR! No text of specified style in document.-1.**

CEM Log Applications System Log

**DataCollectorService1 - DCS for SpectraPak 1** Refresh Service ⓘ

Listening at: net.tcp://172.16.3.12:18591/DCS

**Service Alarm(s)** 3

Started: 9/24/2015 5:48 AM  
Time Now: 10/28/2015 8:26 AM  
Run Time: 1 month, 4 days, 2 hours, 37 mins  
Update Rate: 500 ms  
WCF Fail Rate: 0 / 16522440  
Version: 1.2.2049.0

**Recent Clients**

172.16.100.11	1 month, 3 days, 49 mins
192.168.252.211	1 week, 1 day, 16 hours, 12 mins
172.16.3.12	1 sec
172.16.100.32	Just Now
172.16.100.15	Just Now

**Logger: DataCollectorService1**

Log Time	Severity	Message
----------	----------	---------

Count = 0

**Services List:**

- DataCollectorService1: DCS for SpectraPak 1 @ 4w
- DataCollectorService11: DCS for ModbusMaster @ 4w
- DataCollectorService12: DCS for ModbusMaster @ 4w
- DataCollectorService13
- DataCollectorService14
- DataCollectorService15
- DataCollectorService16: DCS for Hg Analyzer @ 4w
- DataCollectorService17: DCS for Hg Calibrator @ 4w
- DataCollectorService2: DCS for SpectraPak 2 @ 4w
- DataCollectorService9: DCS for ModbusSlave @ 4w
- TagService: Real-time Tag Service @ 2w

Figure Error! No text of specified style in document.-1 Applications Sub-Tab