

3.0 BASIC CONTINUOUS MONITORING REQUIREMENTS

The basic Part 75 continuous monitoring approach is to install CEMS and a DAHS on each affected unit and to record emissions and heat input data. With few exceptions, this general approach must be followed for combustion units that burn coal or any other solid fuel¹³ (see Table 3). Oil-fired and gas-fired units may either comply with the basic CEMS requirements or may use alternative monitoring methods for some or all parameters (see Sections 4, 5, and 6 of this guide for further discussion of these alternative methods).

Table 3: Units that Must Comply with the Basic Part 75 CEMS Requirements

The basic Part 75 CEMS requirements must be met for any unit that . . .
<ul style="list-style-type: none">• Is coal-fired, as defined in 40 CFR §72.2; <p style="text-align: center;"><u>or that</u></p> <ul style="list-style-type: none">• Combusts wood¹², refuse or other material in addition to gas or fuel oil